

Отчет о потреблении тепловой энергии за период
с 21.09.2024 по 21.10.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Кириченко, д. 4А

Тип прибора: БКТ-7
Номер прибора: 74026

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
21.09.2024	24,00	56,91	51,11	5,80	23,430	19,200	4,230	4,000	3,500	4,230	0,303
22.09.2024	24,00	58,26	52,12	6,14	23,390	18,650	4,740	4,000	3,500	4,740	0,335
23.09.2024	24,00	59,08	53,10	5,98	22,670	19,130	3,540	4,000	3,500	3,540	0,282
24.09.2024	24,00	60,40	54,29	6,11	24,210	19,850	4,360	4,000	3,500	4,360	0,331
25.09.2024	24,00	60,70	54,36	6,34	22,620	18,770	3,850	4,000	3,500	3,850	0,304
26.09.2024	24,00	58,53	52,53	6,00	24,210	19,790	4,420	4,000	3,500	4,420	0,326
27.09.2024	24,00	59,45	53,30	6,15	24,010	19,850	4,160	4,000	3,500	4,160	0,317
28.09.2024	24,00	60,94	54,62	6,32	22,160	18,810	3,350	4,000	3,500	3,350	0,279
29.09.2024	24,00	58,69	52,60	6,09	22,790	18,730	4,060	4,000	3,500	4,060	0,304
30.09.2024	24,00	57,68	51,91	5,77	23,220	18,900	4,320	4,000	3,500	4,320	0,307
01.10.2024	24,00	60,43	54,34	6,09	23,630	19,580	4,050	4,000	3,500	4,050	0,312
02.10.2024	24,00	60,12	53,88	6,24	23,480	18,720	4,760	4,000	3,500	4,760	0,343
03.10.2024	24,00	58,96	52,80	6,16	22,970	18,780	4,190	4,000	3,500	4,190	0,309
04.10.2024	24,00	60,03	53,79	6,24	23,430	18,750	4,680	4,000	3,500	4,680	0,342
05.10.2024	24,00	58,68	52,53	6,15	23,170	18,740	4,430	4,000	3,500	4,430	0,320
06.10.2024	24,00	59,17	53,01	6,16	24,280	18,660	5,620	4,000	3,500	5,620	0,381
07.10.2024	24,00	58,76	52,55	6,21	20,880	16,630	4,250	4,000	3,500	4,250	0,300
08.10.2024	24,00	59,82	53,64	6,18	23,210	18,790	4,420	4,000	3,500	4,420	0,326
09.10.2024	24,00	59,73	54,05	5,68	13,730	10,850	2,880	4,000	3,500	2,880	0,200
10.10.2024	24,00	58,62	52,32	6,30	13,400	9,950	3,450	4,000	3,500	3,450	0,223
11.10.2024	24,00	57,84	51,93	5,91	24,700	18,660	6,040	4,000	3,500	6,040	0,387
12.10.2024	24,00	57,64	51,86	5,78	25,080	18,580	6,500	4,000	3,500	6,500	0,408
13.10.2024	24,00	57,89	51,90	5,99	26,680	18,480	8,200	4,000	3,500	8,200	0,492
14.10.2024	24,00	58,33	52,38	5,95	25,770	18,640	7,130	4,000	3,500	7,130	0,446
15.10.2024	24,00	57,62	51,71	5,91	25,670	18,410	7,260	4,000	3,500	7,260	0,445
16.10.2024	24,00	60,31	53,98	6,33	18,020	13,490	4,530	4,000	3,500	4,530	0,302
17.10.2024	24,00	58,80	52,52	6,28	22,470	18,660	3,810	4,000	3,500	3,810	0,297
18.10.2024	24,00	58,59	51,99	6,60	22,390	18,660	3,730	4,000	3,500	3,730	0,295
19.10.2024	24,00	57,85	51,37	6,48	23,170	18,580	4,590	4,000	3,500	4,590	0,333
20.10.2024	24,00	57,76	51,38	6,38	23,940	18,480	5,460	4,000	3,500	5,460	0,371
21.10.2024	24,00	60,15	53,04	7,11	22,330	18,600	3,730	4,000	3,500	3,730	0,309
Среднее	24,00	58,96	52,80	6,16	22,745	18,076	4,669	4,000	3,500	4,669	0,330
Итого	744,00				705,110	560,370	144,740			144,740	10,229

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru