

Отчет о потреблении теплоносителя за период с 21.02.2024 по 22.03.2024

Потребитель: Жилой дом

Тип прибора: ТСРВ-042

Адрес: г. Туапсе, ул. Кронштадтская, д. 3

Номер прибора: 1800565

Дата	Теплосистема 1 - отопление									Теплота (Гкал) Qпод	Теплота (Гкал) Qобр
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, кг/м³	P2, кг/м³		
21.02.2024 23	24,00	73,40	39,57	33,83	35,039	36,219	-1,180	6,016	5,517	1,184	1,226
22.02.2024 23	24,00	72,99	39,25	33,74	35,047	36,223	-1,176	6,016	5,517	1,181	1,222
23.02.2024 23	24,00	74,52	40,13	34,39	35,015	36,141	-1,126	6,016	5,517	1,203	1,243
24.02.2024 23	24,00	71,97	39,33	32,64	35,069	36,202	-1,133	6,016	5,517	1,144	1,182
25.02.2024 23	24,00	72,91	39,64	33,27	34,853	36,059	-1,205	6,016	5,517	1,159	1,200
26.02.2024 23	24,00	68,93	38,34	30,59	35,226	36,325	-1,099	6,016	5,517	1,076	1,110
27.02.2024 23	24,00	72,82	39,58	33,24	34,953	36,169	-1,216	6,016	5,517	1,161	1,202
28.02.2024 23	24,00	71,02	39,03	31,99	35,088	36,296	-1,207	6,016	5,517	1,121	1,161
29.02.2024 23	24,00	72,63	39,52	33,11	35,055	36,190	-1,135	6,016	5,517	1,160	1,199
01.03.2024 23	24,00	72,70	39,50	33,20	34,956	36,230	-1,274	6,016	5,517	1,160	1,203
02.03.2024 23	24,00	71,37	39,33	32,04	35,081	36,212	-1,131	6,016	5,517	1,123	1,160
03.03.2024 23	24,00	71,75	39,61	32,14	34,878	36,159	-1,280	6,016	5,517	1,120	1,162
04.03.2024 23	24,00	72,61	40,33	32,28	34,859	35,999	-1,140	6,016	5,517	1,124	1,162
05.03.2024 23	24,00	63,06	37,63	25,43	35,437	36,642	-1,205	6,016	5,517	0,898	0,929
06.03.2024 23	24,00	70,68	39,33	31,35	34,998	36,162	-1,165	6,016	5,517	1,096	1,134
07.03.2024 23	24,00	69,06	38,73	30,33	35,324	36,518	-1,195	6,016	5,517	1,071	1,108
08.03.2024 23	24,00	70,65	38,72	31,93	35,291	36,538	-1,247	6,016	5,517	1,126	1,167
09.03.2024 23	24,00	69,79	38,70	31,09	35,309	36,479	-1,170	6,016	5,517	1,097	1,134
10.03.2024 23	24,00	69,12	38,35	30,77	35,225	36,474	-1,248	6,016	5,517	1,083	1,122
11.03.2024 23	24,00	65,77	37,41	28,36	35,678	36,853	-1,176	6,016	5,517	1,008	1,041
12.03.2024 23	24,00	70,45	38,90	31,55	35,489	36,625	-1,136	6,016	5,517	1,119	1,156
13.03.2024 23	24,00	69,10	38,82	30,28	35,617	36,894	-1,277	6,016	5,517	1,077	1,117
14.03.2024 23	24,00	70,52	39,76	30,76	35,979	37,099	-1,121	6,016	5,517	1,106	1,141
15.03.2024 23	24,00	70,78	40,27	30,51	35,680	36,913	-1,234	6,016	5,517	1,088	1,127
16.03.2024 23	24,00	71,01	40,51	30,50	35,871	37,079	-1,208	6,016	5,517	1,093	1,131
17.03.2024 23	24,00	64,11	38,41	25,70	36,100	37,296	-1,196	6,016	5,517	0,924	0,955
18.03.2024 23	24,00	71,37	40,85	30,52	35,961	37,123	-1,163	6,016	5,517	1,096	1,133
19.03.2024 23	24,00	70,47	40,50	29,97	36,076	37,307	-1,231	6,016	5,517	1,080	1,118
20.03.2024 23	24,00	72,28	40,84	31,44	34,083	35,315	-1,231	6,016	5,517	1,067	1,107
21.03.2024 23	24,00	63,44	34,16	29,28	22,572	23,361	-0,789	6,016	5,517	0,657	0,680
22.03.2024 23	24,00	67,18	33,99	33,19	22,430	23,193	-0,763	6,016	5,517	0,743	0,769
Среднее	24,00	70,27	39,00	31,27	34,459	35,622	-1,163	6,016	5,517	1,076	1,113
Итого	744,00				1068,237	1104,293	-36,056			33,342	34,499

Показания счетчиков:

Дата и время	M1, т	M2, т	Qтс, Гкал
21.02.2024	17670,004	18065,700	486,760
22.03.2024	18738,241	19169,993	520,102

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru