

Отчет о потреблении теплоносителя за период с 22.01.2024 по 19.02.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Судоремонтников, д. 64

Тип прибора: TCPB-024M
Номер прибора: 1600694

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгвс, Гкал
22.01.2024 23	24,00	48,16	38,17	9,99	41,500	21,580	19,920	5,802	5,792	19,920	0,975
23.01.2024 23	24,00	50,43	39,42	11,01	41,700	22,700	19,000	5,721	5,700	19,000	1,015
24.01.2024 23	24,00	51,45	39,80	11,65	41,500	23,780	17,720	5,802	5,761	17,720	1,003
25.01.2024 23	24,00	52,06	40,54	11,52	42,500	24,110	18,390	5,792	5,751	18,390	1,040
26.01.2024 23	24,00	45,68	36,80	8,88	42,400	23,780	18,620	5,853	5,812	18,620	0,863
27.01.2024 23	24,00	47,73	38,37	9,36	44,600	24,410	20,190	6,037	5,996	20,190	0,978
28.01.2024 23	24,00	48,85	39,24	9,61	45,500	24,300	21,200	5,996	5,945	21,200	1,037
29.01.2024 23	24,00	38,87	32,09	6,78	34,200	18,780	15,420	4,803	4,752	15,420	0,698
30.01.2024 23	24,00	53,88	42,02	11,86	43,100	24,510	18,590	5,894	5,853	18,590	1,100
31.01.2024 23	24,00	54,17	41,66	12,51	41,200	22,800	18,400	5,670	5,639	18,400	1,076
01.02.2024 23	23,13	44,82	35,81	9,01	38,200	19,070	19,130	4,966	4,833	19,130	0,896
02.02.2024 23	24,00	50,86	39,50	11,36	40,900	24,380	16,520	5,925	5,772	16,520	0,955
03.02.2024 23	24,00	53,07	41,13	11,94	42,100	23,520	18,580	5,751	5,517	18,580	1,066
04.02.2024 23	24,00	52,18	40,73	11,45	43,700	24,170	19,530	5,710	5,435	19,530	1,087
05.02.2024 23	24,00	54,61	41,89	12,72	41,000	25,210	15,790	5,751	5,476	15,790	1,015
06.02.2024 23	24,00	55,96	42,84	13,12	41,300	24,730	16,570	5,731	5,425	16,570	1,078
07.02.2024 23	24,00	54,07	42,09	11,98	41,100	24,530	16,570	5,741	5,415	16,570	1,010
08.02.2024 23	24,00	56,37	43,48	12,89	40,900	24,410	16,490	5,659	5,323	16,490	1,067
09.02.2024 23	24,00	57,01	44,49	12,52	41,600	24,860	16,740	5,874	5,517	16,740	1,083
10.02.2024 23	24,00	59,32	45,77	13,55	42,000	25,550	16,450	5,965	5,598	16,450	1,139
11.02.2024 23	24,00	57,98	45,50	12,48	42,800	25,330	17,470	5,945	5,578	17,470	1,130
12.02.2024 23	24,00	58,27	45,39	12,88	41,000	24,950	16,050	5,935	5,568	16,050	1,079
13.02.2024 23	24,00	55,63	44,16	11,47	42,200	25,390	16,810	5,945	5,568	16,810	1,015
14.02.2024 23	24,00	52,67	42,17	10,50	41,200	25,410	15,790	5,914	5,537	15,790	0,925
15.02.2024 23	24,00	53,23	42,52	10,71	41,400	25,940	15,460	5,945	5,557	15,460	0,931
16.02.2024 23	24,00	54,62	43,34	11,28	40,900	25,130	15,770	5,955	5,568	15,770	0,975
17.02.2024 23	24,00	56,79	43,85	12,94	39,100	24,980	14,120	5,731	5,343	14,120	0,969
18.02.2024 23	24,00	56,95	44,76	12,19	42,400	25,590	16,810	5,823	5,415	16,810	1,082
19.02.2024 23	24,00	54,82	43,32	11,50	42,600	25,970	16,630	6,006	5,598	16,630	1,033
Среднее	23,97	52,78	41,41	11,37	40,985	23,933	17,405	5,781	5,553	17,405	1,011
Итого	695,13				1204,600	699,870	504,731			504,731	29,321

Показания счетчиков:

Дата и время	Мтс, т	Wгвс, Гкал
22.01.2024	27071,415	2081,350
19.02.2024	27565,921	2110,671

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46

Подготовлен программным комплексом «Взлет СП». www.vzljot.ru