

Отчет о потреблении теплоносителя за период с 20.02.2024 по 21.03.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Судоремонтников, д. 64

Тип прибора: TCPB-024M
Номер прибора: 1600694

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгвс, Гкал
20.02.2024 23	24,00	54,24	43,36	10,88	43,900	24,930	18,970	5,996	5,568	18,970	1,094
21.02.2024 23	24,00	54,29	42,61	11,68	41,900	24,520	17,380	5,904	5,476	17,380	1,053
22.02.2024 23	24,00	52,86	41,60	11,26	41,900	24,300	17,600	5,863	5,455	17,600	1,016
23.02.2024 23	24,00	53,49	41,81	11,68	42,200	25,330	16,870	6,128	5,690	16,870	1,016
24.02.2024 23	24,00	53,86	42,87	10,99	44,500	25,710	18,790	6,210	5,761	18,790	1,091
25.02.2024 23	24,00	54,21	42,68	11,53	44,200	25,000	19,200	5,874	5,455	19,200	1,124
26.02.2024 23	24,00	54,64	42,64	12,00	41,200	24,380	16,820	5,802	5,404	16,820	1,031
27.02.2024 23	24,00	56,69	43,83	12,86	41,800	24,790	17,010	5,894	5,476	17,010	1,098
28.02.2024 23	24,00	53,41	42,03	11,38	41,700	24,480	17,220	5,751	5,343	17,220	1,013
29.02.2024 23	24,00	53,80	42,31	11,49	42,600	24,750	17,850	5,894	5,476	17,850	1,064
01.03.2024 23	24,00	55,79	43,34	12,45	41,800	24,790	17,010	5,884	5,466	17,010	1,074
02.03.2024 23	24,00	54,02	42,42	11,60	42,100	24,750	17,350	5,741	5,333	17,350	1,040
03.03.2024 23	24,00	55,32	43,66	11,66	43,200	24,800	18,400	5,782	5,364	18,400	1,108
04.03.2024 23	24,00	53,87	42,52	11,35	41,900	25,280	16,620	5,914	5,506	16,620	1,006
05.03.2024 23	24,00	54,37	42,87	11,50	41,200	24,850	16,350	5,894	5,486	16,350	1,000
06.03.2024 23	24,00	54,03	42,53	11,50	40,600	25,030	15,570	5,884	5,486	15,570	0,942
07.03.2024 23	24,00	53,98	42,53	11,45	41,700	26,320	15,380	5,986	5,578	15,380	0,970
08.03.2024 23	24,00	53,06	42,21	10,85	43,100	26,530	16,570	6,139	5,721	16,570	0,984
09.03.2024 23	24,00	54,35	42,23	12,12	40,300	25,580	14,720	5,823	5,425	14,720	0,945
10.03.2024 23	24,00	53,20	41,62	11,58	42,500	24,210	18,290	5,537	5,150	18,290	1,051
11.03.2024 23	24,00	52,81	41,03	11,78	40,500	24,990	15,510	5,731	5,323	15,510	0,952
12.03.2024 23	24,00	53,44	41,97	11,47	42,100	25,190	16,910	5,986	5,568	16,910	1,022
13.03.2024 23	24,00	53,98	42,42	11,56	41,400	24,900	16,500	5,812	5,394	16,500	1,001
14.03.2024 23	24,00	53,60	41,97	11,63	40,300	24,250	16,050	5,792	5,415	16,050	0,966
15.03.2024 23	23,97	56,21	43,52	12,69	40,000	24,230	15,770	5,802	5,455	15,770	1,030
16.03.2024 23	24,00	55,84	43,72	12,12	41,400	24,830	16,570	6,006	5,608	16,570	1,040
17.03.2024 23	24,00	57,27	44,82	12,45	41,600	24,520	17,080	5,904	5,476	17,080	1,090
18.03.2024 23	24,00	54,13	42,66	11,47	40,600	24,530	16,070	6,006	5,517	16,070	0,987
19.03.2024 23	24,00	54,51	43,17	11,34	41,300	24,650	16,650	5,925	5,435	16,650	1,008
20.03.2024 23	24,00	48,16	39,28	8,88	40,300	23,920	16,380	5,802	5,303	16,380	0,807
21.03.2024 23	24,00	54,99	42,53	12,46	37,800	22,290	15,510	5,578	5,129	15,510	0,983
Среднее	24,00	54,14	42,54	11,60	41,090	24,581	16,870	5,879	5,459	16,870	1,020
Итого	743,97				1291,600	768,630	522,971			522,971	31,609

Показания счетчиков:

Дата и время	Мтс, т	Wгвс, Гкал
20.02.2024	27565,921	2110,671
21.03.2024	28077,707	2142,281

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru