

Отчет о потреблении теплоносителя за период с 21.04.2024 по 21.05.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Судоремонтников, д. 64

Тип прибора: TCPB-024M
Номер прибора: 1600694

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгвс, Гкал
21.04.2024 23	24,00	54,44	41,53	12,91	37,600	21,970	15,630	5,466	4,905	15,630	0,981
22.04.2024 23	24,00	54,71	42,58	12,13	40,700	21,610	19,090	5,445	4,895	19,090	1,114
23.04.2024 23	24,00	41,25	30,64	10,61	13,100	8,600	4,500	2,672	2,692	4,500	0,301
24.04.2024 23	24,00	47,64	38,28	9,36	30,700	14,730	15,970	4,395	3,875	15,970	0,899
25.04.2024 23	24,00	58,04	45,21	12,83	37,000	21,240	15,760	5,833	5,109	15,760	1,034
26.04.2024 23	24,00	54,43	43,55	10,88	37,500	21,120	16,380	5,894	5,129	16,380	0,955
27.04.2024 23	24,00	53,78	42,74	11,04	37,600	20,870	16,730	5,863	5,139	16,730	0,956
28.04.2024 23	24,00	56,32	43,75	12,57	35,900	20,440	15,460	5,761	5,078	15,460	0,971
29.04.2024 23	24,00	57,01	44,29	12,72	36,700	21,120	15,580	5,904	5,170	15,580	1,004
30.04.2024 23	24,00	53,78	42,69	11,09	38,800	20,920	17,880	5,914	5,170	17,880	1,005
01.05.2024 23	24,00	55,11	42,42	12,69	37,300	20,930	16,370	5,833	5,048	16,370	1,008
02.05.2024 23	24,00	55,36	42,85	12,51	36,700	20,150	16,550	5,833	5,027	16,550	0,997
03.05.2024 23	24,00	55,15	42,36	12,79	36,500	20,550	15,950	5,904	5,129	15,950	0,993
04.05.2024 23	24,00	53,84	42,42	11,42	38,700	20,010	18,690	5,853	5,017	18,690	1,039
05.05.2024 23	24,00	52,78	40,75	12,03	38,800	19,950	18,850	5,792	4,946	18,850	1,029
06.05.2024 23	24,00	54,38	42,00	12,38	38,100	19,770	18,330	5,863	5,027	18,330	1,059
07.05.2024 23	24,00	55,43	42,11	13,32	36,700	20,220	16,480	5,863	5,078	16,480	1,025
08.05.2024 23	24,00	53,78	41,49	12,29	38,000	20,370	17,630	5,853	5,078	17,630	1,015
09.05.2024 23	24,00	53,41	40,93	12,48	37,300	20,310	16,990	5,833	5,048	16,990	0,990
10.05.2024 23	24,00	57,29	43,16	14,13	35,400	20,470	14,930	5,894	5,078	14,930	0,991
11.05.2024 23	24,00	56,64	42,73	13,91	35,300	20,420	14,880	5,904	5,099	14,880	0,979
12.05.2024 23	24,00	53,70	41,25	12,45	36,400	20,350	16,050	5,833	5,048	16,050	0,952
13.05.2024 23	24,00	55,18	42,17	13,01	37,400	20,320	17,080	5,843	5,048	17,080	1,034
14.05.2024 23	24,00	55,43	41,58	13,85	34,400	18,810	15,590	5,547	4,864	15,590	0,975
15.05.2024 23	24,00	54,65	41,28	13,37	36,000	19,000	17,000	5,639	4,915	17,000	1,018
16.05.2024 23	24,00	54,27	40,94	13,33	35,000	18,990	16,010	5,619	4,884	16,010	0,960
17.05.2024 23	24,00	54,08	40,59	13,49	34,900	18,910	15,990	5,629	4,874	15,990	0,960
18.05.2024 23	24,00	56,02	41,72	14,30	35,400	18,660	16,740	5,608	4,844	16,740	1,036
19.05.2024 23	24,00	54,37	40,85	13,52	35,100	18,740	16,360	5,619	4,905	16,360	0,985
20.05.2024 23	24,00	55,88	41,91	13,97	35,700	19,100	16,600	5,639	4,925	16,600	1,003
21.05.2024 23	24,00	55,16	41,47	13,69	35,400	19,170	16,230	5,619	4,884	16,230	0,994
Среднее	24,00	54,30	41,69	12,62	35,295	19,440	16,203	5,618	4,901	16,203	0,976
Итого	744,00				1110,100	607,820	502,280			502,280	30,263

Показания счетчиков:

Дата и время	Мтс, т	Wгвс, Гкал
21.04.2024	28553,429	2172,045
21.05.2024	29044,932	2202,308

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru