

Отчет о потреблении теплоносителя за период с 21.04.2024 по 21.05.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Фрунзе, д. 36Б

Тип прибора: TCPB-026M
Номер прибора: 1416693

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгв, Гкал
21.04.2024 23	24,00	55,50	44,78	10,72	21,800	19,170	2,630	6,067	5,476	2,630	0,326
22.04.2024 23	24,00	56,22	44,54	11,68	22,300	18,960	3,340	5,853	5,262	3,340	0,374
23.04.2024 23	24,00	34,92	28,78	6,14	7,300	6,840	0,460	2,600	2,753	0,460	0,071
24.04.2024 23	24,00	45,03	36,25	8,78	12,700	10,985	1,715	4,405	3,824	1,715	0,211
25.04.2024 23	24,00	56,79	47,27	9,52	23,700	21,160	2,540	6,567	5,843	2,540	0,325
26.04.2024 23	24,00	55,23	45,69	9,54	24,300	22,420	1,880	6,608	5,853	1,880	0,301
27.04.2024 23	24,00	58,87	47,69	11,18	23,800	22,320	1,480	6,669	5,955	1,480	0,317
28.04.2024 23	24,00	56,33	46,03	10,30	22,400	20,250	2,150	6,669	5,945	2,150	0,307
29.04.2024 23	24,00	57,06	46,05	11,01	23,800	21,140	2,660	6,771	5,965	2,660	0,361
30.04.2024 23	24,00	56,51	45,66	10,85	23,400	21,260	2,140	6,730	5,976	2,140	0,331
01.05.2024 23	24,00	56,07	46,06	10,01	23,500	21,020	2,480	6,679	5,904	2,480	0,328
02.05.2024 23	24,00	54,77	45,11	9,66	23,600	21,070	2,530	6,557	5,914	2,530	0,319
03.05.2024 23	24,00	54,66	44,69	9,97	23,800	21,100	2,700	6,669	5,976	2,700	0,336
04.05.2024 23	24,00	54,69	44,89	9,80	23,900	20,870	3,030	6,710	5,945	3,030	0,346
05.05.2024 23	24,00	56,25	45,70	10,55	23,400	21,090	2,310	6,720	5,996	2,310	0,328
06.05.2024 23	24,00	53,89	44,03	9,86	23,500	21,080	2,420	6,638	5,914	2,420	0,316
07.05.2024 23	24,00	58,04	46,63	11,41	23,400	21,190	2,210	6,720	5,925	2,210	0,340
08.05.2024 23	24,00	55,62	45,37	10,25	23,600	21,220	2,380	6,689	5,935	2,380	0,328
09.05.2024 23	24,00	55,55	45,26	10,29	23,500	21,290	2,210	6,740	6,057	2,210	0,322
10.05.2024 23	24,00	55,61	45,34	10,27	23,100	21,420	1,680	6,659	5,935	1,680	0,295
11.05.2024 23	24,00	55,37	45,24	10,13	23,200	21,210	1,990	6,740	6,037	1,990	0,308
12.05.2024 23	24,00	54,66	44,37	10,29	23,700	20,970	2,730	6,608	5,894	2,730	0,337
13.05.2024 23	24,00	53,84	43,75	10,09	23,500	21,120	2,380	6,710	6,027	2,380	0,317
14.05.2024 23	24,00	54,00	43,69	10,31	23,200	21,100	2,100	6,740	6,006	2,100	0,310
15.05.2024 23	24,00	54,29	44,23	10,06	23,200	21,140	2,060	6,730	5,935	2,060	0,304
16.05.2024 23	24,00	54,02	44,02	10,00	23,100	21,200	1,900	6,638	5,945	1,900	0,296
17.05.2024 23	24,00	54,52	43,99	10,53	23,600	21,180	2,420	6,659	5,935	2,420	0,333
18.05.2024 23	24,00	54,58	44,26	10,32	23,100	21,210	1,890	6,649	5,894	1,890	0,301
19.05.2024 23	24,00	53,45	43,46	9,99	23,500	20,900	2,600	6,445	5,802	2,600	0,319
20.05.2024 23	24,00	53,84	43,83	10,01	23,500	21,260	2,240	6,608	5,914	2,240	0,311
21.05.2024 23	24,00	54,78	44,77	10,01	23,300	21,210	2,090	6,577	5,874	2,090	0,305
Среднее	24,00	54,35	44,24	10,11	22,506	20,270	2,237	6,414	5,729	2,237	0,310
Итого	744,00				697,700	628,355	69,345			69,345	9,620

Показания счетчиков:

Дата и время	Мтс, т	Wгв, Гкал
21.04.2024	2300,136	253,606
21.05.2024	2365,361	263,226

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru