

Отчет о потреблении теплоносителя за период с 22.07.2022 по 21.08.2022

Потребитель: ТСЖ "Солидарность"
Адрес: г. Туапсе, ул. Калараша, д. 46

Тип прибора: ВКТ-7
Номер прибора: 00008456

Дата	Теплосистема 1 - ГВС									Итого по ТС1	
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, кг/м³	P2, кг/м³	Vгвс, м³	W, Гкал
22.07.2022 23	24,00	53,20	45,47	7,73	74,610	63,110	11,500	6,000	5,000	11,500	0,987
23.07.2022 23	24,00	52,50	44,72	7,78	74,700	62,550	12,150	6,000	5,000	12,150	1,003
24.07.2022 23	24,00	54,42	45,96	8,46	76,350	62,060	14,290	6,000	5,000	14,290	1,160
25.07.2022 23	24,00	53,91	45,68	8,23	76,600	62,530	14,070	6,000	5,000	14,070	1,133
26.07.2022 23	24,00	54,50	46,15	8,35	74,750	63,330	11,420	6,000	5,000	11,420	1,035
27.07.2022 23	24,00	54,65	46,30	8,35	75,530	62,970	12,560	6,000	5,000	12,560	1,087
28.07.2022 23	24,00	54,44	46,12	8,32	75,050	62,940	12,110	6,000	5,000	12,110	1,059
29.07.2022 23	24,00	55,52	46,95	8,57	74,690	62,930	11,760	6,000	5,000	11,760	1,076
30.07.2022 23	24,00	56,24	47,40	8,84	74,990	62,600	12,390	6,000	5,000	12,390	1,130
31.07.2022 23	24,00	55,76	47,16	8,60	73,620	62,870	10,750	6,000	5,000	10,750	1,033
01.08.2022 23	24,00	55,73	47,19	8,54	73,480	63,340	10,140	6,000	5,000	10,140	1,005
02.08.2022 23	24,00	56,72	47,97	8,75	74,080	63,460	10,620	6,000	5,000	10,620	1,055
03.08.2022 23	24,00	56,88	48,10	8,78	72,830	63,230	9,600	6,000	5,000	9,600	1,004
04.08.2022 23	24,00	56,30	47,55	8,75	72,280	63,390	8,890	6,000	5,000	8,890	0,968
05.08.2022 23	24,00	56,00	47,39	8,61	72,010	63,200	8,810	6,000	5,000	8,810	0,949
06.08.2022 23	24,00	56,10	47,46	8,64	72,280	62,490	9,790	6,000	5,000	9,790	0,992
07.08.2022 23	24,00	56,27	47,48	8,79	72,850	62,150	10,700	6,000	5,000	10,700	1,042
08.08.2022 23	24,00	56,34	47,77	8,57	72,440	62,770	9,670	6,000	5,000	9,670	0,989
09.08.2022 23	24,00	56,44	47,88	8,56	73,140	62,630	10,510	6,000	5,000	10,510	1,024
10.08.2022 23	24,00	58,69	49,24	9,45	68,560	58,050	10,510	6,000	5,000	10,510	1,061
11.08.2022 23	24,00	50,94	42,21	8,73	57,980	44,870	13,110	6,000	5,000	13,110	0,927
12.08.2022 23	24,00	56,92	48,06	8,86	67,210	55,600	11,610	6,000	5,000	11,610	1,036
13.08.2022 23	24,00	56,28	47,80	8,48	73,300	63,010	10,290	6,000	5,000	10,290	1,009
14.08.2022 23	24,00	55,59	47,42	8,17	74,340	62,740	11,600	6,000	5,000	11,600	1,041
15.08.2022 23	24,00	55,90	47,67	8,23	74,980	63,530	11,450	6,000	5,000	11,450	1,047
16.08.2022 23	24,00	55,90	47,64	8,26	73,540	63,560	9,980	6,000	5,000	9,980	0,980
17.08.2022 23	24,00	55,71	47,44	8,27	73,820	63,650	10,170	6,000	5,000	10,170	0,992
18.08.2022 23	24,00	56,38	47,98	8,40	73,940	63,510	10,430	6,000	5,000	10,430	1,020
19.08.2022 23	24,00	55,38	47,34	8,04	74,140	63,730	10,410	6,000	5,000	10,410	0,984
20.08.2022 23	24,00	56,26	47,77	8,49	73,540	63,020	10,520	6,000	5,000	10,520	1,023
21.08.2022 23	24,00	56,07	47,67	8,40	74,230	62,850	11,380	6,000	5,000	11,380	1,053
Среднее	24,00	55,55	47,06	8,48	73,092	62,022	11,071	6,000	5,000	11,071	1,029
Итого	744,00				1922,670	1922,670	343,190			343,190	31,904

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
е-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru