

Отчет о потреблении теплоносителя за период с 21.04.2022 по 21.05.2022

Потребитель: ТСЖ "Солидарность"
Адрес: г. Туапсе, ул. Калараша, д. 46

Тип прибора: ВКТ-7
Номер прибора: 00282016

Дата	Теплосистема 1 - ГВС									Итого по ТС1	
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, кг/м³	P2, кг/м³	Vгвс, м³	W, Гкал
21.04.2022 23	24,00	59,17	47,31	11,86	78,760	62,050	16,710	5,000	3,500	16,710	1,557
22.04.2022 23	24,00	58,00	46,53	11,47	77,510	62,710	14,800	5,000	3,500	14,800	1,429
23.04.2022 23	24,00	58,22	46,79	11,43	78,490	61,900	16,590	5,000	3,500	16,590	1,507
24.04.2022 23	24,00	60,03	48,27	11,76	78,050	61,770	16,280	5,000	3,500	16,280	1,539
25.04.2022 23	24,00	61,22	49,08	12,14	76,100	62,610	13,490	5,000	3,500	13,490	1,453
26.04.2022 23	24,00	57,04	46,71	10,33	76,510	62,370	14,140	5,000	3,500	14,140	1,309
27.04.2022 23	24,00	59,55	48,13	11,42	76,340	62,460	13,880	5,000	3,500	13,880	1,402
28.04.2022 23	24,00	57,77	46,87	10,90	74,670	62,250	12,420	5,000	3,500	12,420	1,275
29.04.2022 23	24,00	59,51	48,03	11,48	77,330	62,240	15,090	5,000	3,500	15,090	1,464
30.04.2022 23	24,00	60,19	48,36	11,83	76,820	61,890	14,930	5,000	3,500	14,930	1,481
01.05.2022 23	24,00	59,01	47,52	11,49	75,510	61,480	14,030	5,000	3,500	14,030	1,392
02.05.2022 23	24,00	58,39	46,97	11,42	75,670	62,140	13,530	5,000	3,500	13,530	1,363
03.05.2022 23	24,00	59,06	47,46	11,60	77,520	61,670	15,850	5,000	3,500	15,850	1,494
04.05.2022 23	24,00	59,67	47,84	11,83	77,490	62,520	14,970	5,000	3,500	14,970	1,483
05.05.2022 23	24,00	59,20	47,68	11,52	75,650	62,490	13,160	5,000	3,500	13,160	1,367
06.05.2022 23	24,00	57,25	46,23	11,02	75,770	61,160	14,610	5,000	3,500	14,610	1,366
07.05.2022 23	24,00	58,11	46,69	11,42	76,830	63,190	13,640	5,000	3,500	13,640	1,376
08.05.2022 23	24,00	58,57	46,99	11,58	78,050	61,940	16,110	5,000	3,500	16,110	1,499
09.05.2022 23	24,00	59,45	47,73	11,72	75,960	62,130	13,830	5,000	3,500	13,830	1,410
10.05.2022 23	24,00	58,48	46,97	11,51	76,940	61,790	15,150	5,000	3,500	15,150	1,444
11.05.2022 23	24,00	58,44	46,82	11,62	76,490	61,950	14,540	5,000	3,500	14,540	1,423
12.05.2022 23	24,00	58,01	46,68	11,33	76,800	61,750	15,050	5,000	3,500	15,050	1,423
13.05.2022 23	24,00	57,04	45,99	11,05	77,480	62,700	14,780	5,000	3,500	14,780	1,388
14.05.2022 23	24,00	58,50	47,13	11,37	78,350	62,060	16,290	5,000	3,500	16,290	1,499
15.05.2022 23	24,00	58,42	47,07	11,35	78,180	62,110	16,070	5,000	3,500	16,070	1,485
16.05.2022 23	24,00	59,13	47,91	11,22	76,510	62,530	13,980	5,000	3,500	13,980	1,387
17.05.2022 23	24,00	59,36	48,01	11,35	75,720	62,850	12,870	5,000	3,500	12,870	1,351
18.05.2022 23	24,00	58,50	47,53	10,97	77,170	62,440	14,730	5,000	3,500	14,730	1,400
19.05.2022 23	24,00	57,47	46,64	10,83	75,520	62,850	12,670	5,000	3,500	12,670	1,282
20.05.2022 23	24,00	57,09	46,39	10,70	78,130	62,480	15,650	5,000	3,500	15,650	1,406
21.05.2022 23	24,00	58,33	47,18	11,15	76,790	62,270	14,520	5,000	3,500	14,520	1,396
Среднее	24,00	58,65	47,27	11,38	76,875	62,218	14,657	5,000	3,500	14,657	1,421
Итого	744,00				1928,750	1928,750	454,360			454,360	44,050

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
е-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru