

Отчет о потреблении теплоносителя за период с 22.08.2022 по 20.09.2022

Потребитель: ТСЖ "Солидарность"

Адрес: г. Туапсе, ул. Калараша, д. 46

Тип прибора: ВКТ-7

Номер прибора: 00008456

Дата	Теплосистема 1 - ГВС									Итого по ТС1	
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, кг/м³	P2, кг/м³	Vгвс, м³	W, Гкал
22.08.2022 23	24,00	56,18	47,85	8,33	73,170	63,390	9,780	6,000	5,000	9,780	0,978
23.08.2022 23	24,00	55,89	46,97	8,92	65,290	54,830	10,460	6,000	5,000	10,460	0,971
24.08.2022 23	24,00	56,86	48,11	8,75	71,060	60,170	10,890	6,000	5,000	10,890	1,035
25.08.2022 23	24,00	56,55	47,88	8,67	70,910	60,170	10,740	6,000	5,000	10,740	1,021
26.08.2022 23	24,00	57,07	48,27	8,80	70,060	60,100	9,960	6,000	5,000	9,960	0,998
27.08.2022 23	24,00	56,70	47,87	8,83	70,650	59,370	11,280	6,000	5,000	11,280	1,049
28.08.2022 23	24,00	56,81	47,98	8,83	69,930	59,680	10,250	6,000	5,000	10,250	1,007
29.08.2022 23	24,00	55,96	47,34	8,62	69,320	60,150	9,170	6,000	5,000	9,170	0,939
30.08.2022 23	24,00	56,62	47,77	8,85	69,790	59,950	9,840	6,000	5,000	9,840	0,990
31.08.2022 23	24,00	56,52	47,65	8,87	69,710	59,750	9,960	6,000	5,000	9,960	0,993
01.09.2022 23	24,00	56,63	47,69	8,94	69,190	59,710	9,480	6,000	5,000	9,480	0,978
02.09.2022 23	24,00	56,15	47,44	8,71	69,450	59,850	9,600	6,000	5,000	9,600	0,965
03.09.2022 23	24,00	55,14	46,77	8,37	69,980	59,160	10,820	6,000	5,000	10,820	0,984
04.09.2022 23	24,00	55,03	46,60	8,43	69,660	58,990	10,670	6,000	5,000	10,670	0,979
05.09.2022 23	24,00	53,26	45,06	8,20	71,590	59,000	12,590	6,000	5,000	12,590	1,031
06.09.2022 23	24,00	53,21	44,76	8,45	70,470	59,120	11,350	6,000	5,000	11,350	0,990
07.09.2022 23	24,00	52,06	43,12	8,94	56,310	43,900	12,410	6,000	5,000	12,410	0,915
08.09.2022 23	24,00	52,80	44,41	8,39	73,880	62,400	11,480	6,000	5,000	11,480	1,018
09.09.2022 23	24,00	53,67	44,87	8,80	73,580	62,050	11,530	6,000	5,000	11,530	1,048
10.09.2022 23	24,00	55,60	46,56	9,04	74,710	61,590	13,120	6,000	5,000	13,120	1,158
11.09.2022 23	24,00	54,31	45,44	8,87	74,350	61,600	12,750	6,000	5,000	12,750	1,111
12.09.2022 23	24,00	54,00	45,60	8,40	74,000	62,300	11,700	6,000	5,000	11,700	1,039
13.09.2022 23	24,00	53,09	45,07	8,02	73,190	62,700	10,490	6,000	5,000	10,490	0,956
14.09.2022 23	24,00	50,46	43,13	7,33	76,970	62,400	14,570	6,000	5,000	14,570	1,047
15.09.2022 23	24,00	49,18	42,06	7,12	75,250	62,240	13,010	6,000	5,000	13,010	0,953
16.09.2022 23	24,00	51,03	43,25	7,78	76,210	62,000	14,210	6,000	5,000	14,210	1,067
17.09.2022 23	24,00	55,26	46,51	8,75	73,990	61,650	12,340	6,000	5,000	12,340	1,098
18.09.2022 23	24,00	54,98	46,51	8,47	75,510	61,200	14,310	6,000	5,000	14,310	1,163
19.09.2022 23	24,00	54,57	46,17	8,40	73,540	61,800	11,740	6,000	5,000	11,740	1,045
20.09.2022 23	24,00	54,73	46,28	8,45	74,970	61,650	13,320	6,000	5,000	13,320	1,115
Среднее	24,00	54,68	46,17	8,51	71,556	60,096	11,461	6,000	5,000	11,461	1,021
Итого	720,00				1802,870	1802,870	343,820			343,820	30,641

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
е-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru