

Отчет о потреблении теплоносителя за период с 22.05.2022 по 20.06.2022

Потребитель: ТСЖ "Солидарность"
Адрес: г. Туапсе, ул. Калараша, д. 46

Тип прибора: ВКТ-7
Номер прибора: 00282016

Дата	Теплосистема 1 - ГВС									Итого по ТС1	
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, кг/м³	P2, кг/м³	Vгвс, м³	W, Гкал
22.05.2022 23	24,00	58,39	47,22	11,17	77,270	61,910	15,360	5,000	3,500	15,360	1,432
23.05.2022 23	24,00	58,40	47,36	11,04	75,670	62,790	12,880	5,000	3,500	12,880	1,315
24.05.2022 23	24,00	58,20	47,29	10,91	77,850	62,550	15,300	5,000	3,500	15,300	1,421
25.05.2022 23	24,00	58,34	47,24	11,10	77,140	62,510	14,630	5,000	3,500	14,630	1,399
26.05.2022 23	24,00	58,76	47,42	11,34	75,740	62,450	13,290	5,000	3,500	13,290	1,354
27.05.2022 23	24,00	55,24	45,26	9,98	77,330	62,270	15,060	5,000	3,500	15,060	1,307
28.05.2022 23	24,00	61,50	49,25	12,25	76,760	62,010	14,750	5,000	3,500	14,750	1,518
29.05.2022 23	24,00	62,20	50,17	12,03	79,420	61,580	17,840	5,000	3,500	17,840	1,674
30.05.2022 23	24,00	36,04	35,95	0,09	35,560	25,890	9,670	5,000	3,500	9,670	0,254
31.05.2022 23	24,00	23,14	23,76	-0,62	0,000	0,000	0,000	5,000	3,500	0,000	0,000
01.06.2022 23	24,00	23,51	24,08	-0,57	0,000	0,000	0,000	5,000	3,500	0,000	0,000
02.06.2022 23	24,00	23,57	25,58	-2,01	0,000	0,000	0,000	5,000	3,500	0,000	0,000
03.06.2022 23	24,00	58,39	50,90	7,49	10,810	6,390	4,420	5,000	3,500	4,420	0,261
04.06.2022 23	24,00	60,62	50,60	10,02	67,800	53,130	14,670	5,000	3,500	14,670	1,275
05.06.2022 23	24,00	59,07	48,91	10,16	80,600	66,070	14,530	5,000	3,500	14,530	1,383
06.06.2022 23	24,00	60,13	50,07	10,06	79,560	66,530	13,030	5,000	3,500	13,030	1,324
07.06.2022 23	24,00	60,23	50,10	10,13	78,110	66,180	11,930	5,000	3,500	11,930	1,270
08.06.2022 23	24,00	59,90	49,61	10,29	76,130	63,590	12,540	5,000	3,500	12,540	1,283
09.06.2022 23	24,00	59,08	48,88	10,20	73,950	63,460	10,490	5,000	3,500	10,490	1,164
10.06.2022 23	24,00	58,55	48,65	9,90	76,230	63,530	12,700	5,000	3,500	12,700	1,243
11.06.2022 23	24,00	58,88	49,02	9,86	75,520	62,530	12,990	5,000	3,500	12,990	1,251
12.06.2022 23	24,00	58,95	49,15	9,80	77,120	62,290	14,830	5,000	3,500	14,830	1,334
13.06.2022 23	24,00	59,05	49,32	9,73	76,810	62,270	14,540	5,000	3,500	14,540	1,318
14.06.2022 23	24,00	58,67	49,06	9,61	76,370	62,810	13,560	5,000	3,500	13,560	1,264
15.06.2022 23	24,00	58,84	49,31	9,53	75,670	62,590	13,080	5,000	3,500	13,080	1,237
16.06.2022 23	24,00	58,98	49,25	9,73	75,450	62,840	12,610	5,000	3,500	12,610	1,229
17.06.2022 23	24,00	59,51	49,65	9,86	75,440	62,890	12,550	5,000	3,500	12,550	1,243
18.06.2022 23	24,00	59,91	49,80	10,11	75,520	62,330	13,190	5,000	3,500	13,190	1,287
19.06.2022 23	24,00	60,03	50,06	9,97	76,140	62,220	13,920	5,000	3,500	13,920	1,316
20.06.2022 23	24,00	57,95	48,76	9,19	76,520	62,740	13,780	5,000	3,500	13,780	1,235
Среднее	24,00	54,80	46,06	8,75	65,216	53,278	11,938	5,000	3,500	11,938	1,120
Итого	720,00				1598,350	1598,350	358,140			358,140	33,591

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
е-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru