

Отчет о потреблении тепловой энергии за период с 22.10.2024 по 20.11.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Кириченко, д. 4А

Тип прибора: ВКТ-7
Номер прибора: 74026

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
22.10.2024	24,00	59,72	52,78	6,94	23,100	18,420	4,680	4,000	3,500	4,680	0,350
23.10.2024	24,00	58,35	52,86	5,49	8,480	6,920	1,560	4,000	3,500	1,560	0,108
24.10.2024	24,00	52,49	48,31	4,18	14,230	10,250	3,980	4,000	3,500	3,980	0,209
25.10.2024	24,00	56,88	50,49	6,39	23,130	18,330	4,800	4,000	3,500	4,800	0,338
26.10.2024	24,00	58,04	50,80	7,24	21,990	18,320	3,670	4,000	3,500	3,670	0,302
27.10.2024	25,00	57,69	50,95	6,74	23,620	19,040	4,580	4,000	3,500	4,580	0,343
28.10.2024	24,00	58,66	51,90	6,76	22,410	18,280	4,130	4,000	3,500	4,130	0,318
29.10.2024	24,00	58,15	51,45	6,70	22,060	18,360	3,700	4,000	3,500	3,700	0,297
30.10.2024	24,00	57,52	51,07	6,45	22,670	18,320	4,350	4,000	3,500	4,350	0,319
31.10.2024	24,00	59,48	52,54	6,94	22,310	18,390	3,920	4,000	3,500	3,920	0,315
01.11.2024	24,00	58,54	51,88	6,66	22,630	18,360	4,270	4,000	3,500	4,270	0,324
02.11.2024	24,00	59,59	52,70	6,89	22,340	18,370	3,970	4,000	3,500	3,970	0,316
03.11.2024	24,00	56,68	49,93	6,75	23,160	18,280	4,880	4,000	3,500	4,880	0,343
04.11.2024	24,00	58,09	51,32	6,77	23,150	18,330	4,820	4,000	3,500	4,820	0,347
05.11.2024	24,00	59,36	52,51	6,85	22,530	18,430	4,100	4,000	3,500	4,100	0,319
06.11.2024	24,00	59,00	52,22	6,78	22,170	18,430	3,740	4,000	3,500	3,740	0,302
07.11.2024	24,00	59,74	52,91	6,83	22,500	18,480	4,020	4,000	3,500	4,020	0,318
08.11.2024	24,00	58,56	51,72	6,84	22,800	18,390	4,410	4,000	3,500	4,410	0,332
09.11.2024	24,00	60,16	52,87	7,29	22,690	18,450	4,240	4,000	3,500	4,240	0,338
10.11.2024	24,00	58,75	51,81	6,94	22,810	18,410	4,400	4,000	3,500	4,400	0,335
11.11.2024	24,00	57,56	51,19	6,37	22,680	18,390	4,290	4,000	3,500	4,290	0,315
12.11.2024	24,00	59,18	52,56	6,62	22,160	18,420	3,740	4,000	3,500	3,740	0,298
13.11.2024	24,00	59,71	52,85	6,86	22,370	18,450	3,920	4,000	3,500	3,920	0,312
14.11.2024	24,00	59,00	52,46	6,54	22,210	18,410	3,800	4,000	3,500	3,800	0,300
15.11.2024	24,00	56,59	50,35	6,24	22,690	18,380	4,310	4,000	3,500	4,310	0,313
16.11.2024	24,00	58,26	51,18	7,08	22,700	18,360	4,340	4,000	3,500	4,340	0,334
17.11.2024	24,00	58,77	51,73	7,04	23,110	18,300	4,810	4,000	3,500	4,810	0,355
18.11.2024	24,00	59,26	52,24	7,02	22,310	18,360	3,950	4,000	3,500	3,950	0,317
19.11.2024	24,00	59,31	52,56	6,75	22,490	18,370	4,120	4,000	3,500	4,120	0,318
20.11.2024	24,00	59,88	52,42	7,46	21,950	18,400	3,550	4,000	3,500	3,550	0,304
Среднее	24,03	58,43	51,75	6,68	21,848	17,747	4,102	4,000	3,500	4,102	0,311
Итого	721,00				655,450	532,400	123,050			123,050	9,339

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru