

Отчет о потреблении теплоносителя за период с 20.12.2024 по 19.01.2025

Потребитель: МБОУ СОШ №4

Тип прибора: ТСРВ-042

Адрес: г. Туапсе, ул. Максима Горького, д. 40

Номер прибора: 1601111

Дата	Теплосистема 1 - отопление									Теплота (Гкал) Qпод	Теплота (Гкал) Qобр
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, кг/м³	P2, кг/м³		
20.12.2024 23	24,00	61,49	49,46	12,03	237,037	233,884	3,153	6,016	5,517	2,849	2,811
21.12.2024 23	24,00	60,22	48,76	11,46	237,138	234,023	3,115	6,016	5,517	2,715	2,682
22.12.2024 23	24,00	56,71	46,39	10,32	237,172	234,173	2,999	6,016	5,517	2,446	2,419
23.12.2024 23	24,00	57,21	46,80	10,41	237,505	234,502	3,003	6,016	5,517	2,469	2,439
24.12.2024 23	24,00	58,81	48,15	10,66	238,590	235,524	3,066	6,016	5,517	2,543	2,511
25.12.2024 23	24,00	57,81	48,06	9,75	258,115	254,673	3,442	6,016	5,517	2,509	2,478
26.12.2024 23	24,00	56,48	46,50	9,98	234,950	231,627	3,324	6,016	5,517	2,343	2,312
27.12.2024 23	24,00	58,17	47,61	10,56	235,770	232,382	3,388	6,016	5,517	2,487	2,454
28.12.2024 23	23,18	55,50	45,58	9,92	235,056	231,747	3,309	6,016	5,517	2,327	2,297
29.12.2024 23	24,00	56,26	45,86	10,40	234,581	231,273	3,309	6,016	5,517	2,437	2,405
30.12.2024 23	24,00	56,76	46,19	10,57	234,366	231,072	3,295	6,016	5,517	2,476	2,445
31.12.2024 23	24,00	56,94	46,34	10,60	234,439	231,128	3,311	6,016	5,517	2,483	2,452
01.01.2025 23	24,00	55,49	45,36	10,13	234,495	231,186	3,309	6,016	5,517	2,372	2,340
02.01.2025 23	24,00	56,04	45,84	10,20	234,560	231,264	3,296	6,016	5,517	2,391	2,361
03.01.2025 23	24,00	55,48	45,50	9,98	234,594	231,297	3,297	6,016	5,517	2,338	2,306
04.01.2025 23	24,00	54,16	44,61	9,55	234,678	231,395	3,283	6,016	5,517	2,240	2,210
05.01.2025 23	24,00	57,70	46,75	10,95	234,134	230,815	3,319	6,016	5,517	2,562	2,527
06.01.2025 23	24,00	60,20	48,46	11,74	234,096	230,720	3,376	6,016	5,517	2,746	2,709
07.01.2025 23	24,00	55,46	45,29	10,17	234,127	230,857	3,270	6,016	5,517	2,379	2,348
08.01.2025 23	24,00	55,69	45,46	10,23	234,042	230,779	3,263	6,016	5,517	2,392	2,359
09.01.2025 23	24,00	55,60	45,53	10,07	234,224	230,968	3,256	6,016	5,517	2,357	2,328
10.01.2025 23	24,00	55,65	45,73	9,92	234,876	231,635	3,241	6,016	5,517	2,329	2,298
11.01.2025 23	24,00	55,57	45,69	9,88	234,373	231,120	3,253	6,016	5,517	2,312	2,281
12.01.2025 23	24,00	55,59	45,48	10,11	234,612	230,539	4,073	6,016	5,517	2,370	2,331
13.01.2025 23	24,00	54,99	45,04	9,95	234,725	231,435	3,290	6,016	5,517	2,335	2,305
14.01.2025 23	24,00	56,07	45,68	10,39	234,064	230,798	3,266	6,016	5,517	2,430	2,398
15.01.2025 23	24,00	56,41	45,97	10,44	234,072	230,802	3,270	6,016	5,517	2,441	2,410
16.01.2025 23	24,00	56,88	46,12	10,76	234,636	230,931	3,706	6,016	5,517	2,524	2,487
17.01.2025 23	24,00	56,70	45,83	10,87	235,699	232,402	3,296	6,016	5,517	2,559	2,526
18.01.2025 23	24,00	54,29	44,07	10,22	235,088	231,873	3,215	6,016	5,517	2,400	2,370
19.01.2025 23	24,00	54,16	43,92	10,24	234,987	231,786	3,201	6,016	5,517	2,404	2,373
Среднее	23,97	56,60	46,19	10,40	235,832	232,536	3,297	6,016	5,517	2,450	2,418
Итого	743,18				7310,803	7208,611	102,192			75,965	74,970

Показания счетчиков:

Дата и время	M1, т	M2, т	Qтс, Гкал
20.12.2024	101310,571	99717,389	1056,836
19.01.2025	108621,374	106926,000	1132,801

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru