

Отчет о потреблении тепловой энергии и теплоносителя с 22.03.2025 по 20.04.2025

Прибор Прибор: КАРАТ-307 (04990617)
Потребитель Жилой дом
Адрес узла г. Туапсе, ул. Маршала Жукова, д. 25

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, МПа	P2, МПа	W, Гкал
22.03.2025	24.00	57.43	43.63	13.80	95.929	91.309	4.620	0.35	0.63	1.317
23.03.2025	24.00	57.93	44.01	13.93	96.004	91.415	4.588	0.35	0.62	1.330
24.03.2025	24.00	54.91	42.33	12.58	96.787	91.981	4.806	0.35	0.63	1.210
25.03.2025	24.00	52.88	41.34	11.55	98.070	93.137	4.933	0.35	0.61	1.126
26.03.2025	24.00	53.54	42.13	11.41	98.526	93.563	4.963	0.36	0.62	1.117
27.03.2025	24.00	55.65	43.68	11.97	98.571	93.664	4.907	0.36	0.62	1.173
28.03.2025	24.00	53.17	41.91	11.26	91.636	87.055	4.581	0.36	0.63	1.011
29.03.2025	24.00	21.59	19.19	2.40	0.098	0.084	0.014	0.36	0.53	0.001
30.03.2025	24.00	17.91	17.03	0.88	0.000	0.000	0.000	0.36	0.55	0.000
31.03.2025	24.00	34.09	28.30	5.78	54.987	52.531	2.456	0.35	0.60	0.535
01.04.2025	24.00	53.81	42.49	11.32	98.016	93.301	4.715	0.36	0.62	1.103
02.04.2025	24.00	36.09	29.41	6.68	37.486	35.661	1.825	0.36	0.59	0.414
03.04.2025	24.00	49.56	39.52	10.04	98.595	94.065	4.530	0.36	0.64	0.982
04.04.2025	24.00	54.08	42.72	11.36	98.457	93.612	4.845	0.36	0.64	1.112
05.04.2025	24.00	55.26	43.52	11.74	99.066	94.240	4.826	0.36	0.62	1.156
06.04.2025	24.00	54.36	43.02	11.35	99.006	94.246	4.760	0.36	0.63	1.116
07.04.2025	24.00	54.95	43.74	11.21	99.649	94.750	4.899	0.36	0.64	1.110
08.04.2025	24.00	55.29	43.49	11.80	99.020	93.945	5.075	0.36	0.64	1.162
09.04.2025	24.00	55.89	43.48	12.41	98.922	93.906	5.016	0.36	0.63	1.221
10.04.2025	24.00	55.36	43.10	12.26	99.433	94.327	5.106	0.36	0.62	1.212
11.04.2025	24.00	55.13	42.89	12.24	99.127	94.103	5.024	0.36	0.62	1.207
12.04.2025	24.00	55.16	42.72	12.44	98.614	93.563	5.051	0.36	0.61	1.220
13.04.2025	24.00	54.40	42.12	12.28	98.380	93.507	4.873	0.36	0.63	1.201
14.04.2025	24.00	53.48	41.81	11.67	99.318	94.416	4.902	0.36	0.63	1.152
15.04.2025	24.00	39.93	33.44	6.49	41.404	39.316	2.088	0.35	0.59	0.519
16.04.2025	24.00	18.96	19.31	-0.35	0.023	0.026	-0.003	0.35	0.57	0.000
17.04.2025	24.00	16.05	15.90	0.15	0.000	0.000	0.000	0.34	0.56	0.000
18.04.2025	24.00	16.16	15.37	0.79	0.000	0.000	0.000	0.34	0.55	0.000
19.04.2025	24.00	16.25	15.54	0.71	0.000	0.000	0.000	0.34	0.56	0.000
20.04.2025	24.00	15.93	15.72	0.22	0.000	0.000	0.000	0.34	0.57	0.000
Среднее	24.00	44.17	35.43	8.75	69.837	66.391	3.447	0.35	0.61	0.824
Итого	720.00				2,095.122	1,991.723	103.399			24.707

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 3
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46