

Отчет о потреблении теплоносителя за период с 20.01.2025 по 17.02.2025

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Новицкого, д. 17

Тип прибора: TCPB-024M
Номер прибора: 1204472

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгвс, Гкал
20.01.2025 23	24,00	63,46	57,52	5,94	135,268	127,388	7,880	3,997	3,498	7,880	1,135
21.01.2025 23	24,00	62,55	56,81	5,74	133,191	124,893	8,298	3,997	3,498	8,298	1,114
22.01.2025 23	24,00	66,48	59,77	6,71	126,849	119,526	7,322	3,997	3,498	7,322	1,147
23.01.2025 23	24,00	57,37	49,39	7,98	105,971	98,089	7,882	3,997	3,498	7,882	0,946
24.01.2025 23	24,00	62,81	57,12	5,69	134,561	127,017	7,544	3,997	3,498	7,544	1,071
25.01.2025 23	24,00	59,02	53,83	5,19	133,580	124,797	8,783	3,997	3,498	8,783	1,027
26.01.2025 23	24,00	63,48	57,63	5,85	133,231	123,830	9,401	3,997	3,498	9,401	1,171
27.01.2025 23	24,00	63,60	57,69	5,91	132,800	125,994	6,806	3,997	3,498	6,806	1,069
28.01.2025 23	24,00	64,62	58,52	6,10	133,800	125,660	8,140	3,997	3,498	8,140	1,162
29.01.2025 23	24,00	63,84	57,85	5,99	133,586	126,368	7,218	3,997	3,498	7,218	1,102
30.01.2025 23	24,00	61,32	55,58	5,74	127,813	120,112	7,701	3,997	3,498	7,701	1,021
31.01.2025 23	24,00	58,02	50,02	8,00	106,657	99,394	7,263	3,997	3,498	7,263	0,941
01.02.2025 23	24,00	65,05	58,83	6,22	133,258	126,498	6,760	3,997	3,498	6,760	1,116
02.02.2025 23	24,00	64,42	58,43	5,99	132,338	124,781	7,557	3,997	3,498	7,557	1,109
03.02.2025 23	24,00	58,92	53,68	5,24	126,431	118,893	7,537	3,997	3,498	7,537	0,933
04.02.2025 23	24,00	58,61	51,30	7,31	106,319	98,980	7,339	3,997	3,498	7,339	0,945
05.02.2025 23	24,00	65,23	59,00	6,23	134,745	128,001	6,744	3,997	3,498	6,744	1,127
06.02.2025 23	24,00	65,80	59,47	6,33	133,719	126,653	7,066	3,997	3,498	7,066	1,146
07.02.2025 23	23,97	60,09	55,37	4,72	112,136	105,462	6,674	3,997	3,498	6,674	1,008
08.02.2025 23	24,00	64,88	58,68	6,20	135,242	128,180	7,062	3,997	3,498	7,062	1,134
09.02.2025 23	24,00	63,64	57,50	6,14	133,812	124,676	9,136	3,997	3,498	9,136	1,204
10.02.2025 23	24,00	65,39	58,95	6,44	132,670	125,316	7,354	3,997	3,498	7,354	1,166
11.02.2025 23	24,00	65,42	58,90	6,52	127,451	120,403	7,048	3,997	3,498	7,048	1,116
12.02.2025 23	24,00	59,09	50,47	8,62	104,518	97,280	7,239	3,997	3,498	7,239	0,966
13.02.2025 23	24,00	65,72	59,40	6,32	134,182	126,006	8,176	3,997	3,498	8,176	1,200
14.02.2025 23	24,00	65,93	59,56	6,37	132,174	125,615	6,559	3,997	3,498	6,559	1,118
15.02.2025 23	24,00	64,32	58,24	6,08	131,380	123,851	7,529	3,997	3,498	7,529	1,116
16.02.2025 23	24,00	62,78	56,90	5,88	131,122	122,840	8,282	3,997	3,498	8,282	1,116
17.02.2025 23	24,00	63,94	57,65	6,29	130,126	123,455	6,671	3,997	3,498	6,671	1,092
Среднее	24,00	62,96	56,69	6,27	125,501	118,463	7,551	3,997	3,498	7,551	1,087
Итого	695,97				3708,931	3489,959	218,972			218,972	31,519

Показания счетчиков:

Дата и время	Мтс, т	Wгвс, Гкал
20.01.2025	4274,977	617,534
17.02.2025	4479,087	649,052

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru