

Отчет о потреблении тепловой энергии и теплоносителя за период с 20.12.2024 по 19.01.2025

Потребитель: Жилой дом

Адрес: г. Туапсе, ул. Октябрьской Революции, д. 1

Тип прибора: СПТ941.20

Номер прибора: 97481

Дата	Теплосистема 1 - отопление									Теплота (Гкал) Qпод	Теплота (Гкал) Qобр
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, кг/м³	P2, кг/м³		
20.12.2024 23	24,00	73,03	49,26	23,77	81,461	79,924	1,537	6,000	5,500	1,934	1,900
21.12.2024 23	24,00	73,18	49,57	23,61	81,373	79,898	1,475	6,000	5,500	1,919	1,886
22.12.2024 23	24,00	71,36	48,82	22,55	80,880	79,513	1,367	6,000	5,500	1,822	1,793
23.12.2024 23	24,00	68,06	47,42	20,64	80,670	79,210	1,459	6,000	5,500	1,663	1,635
24.12.2024 23	24,00	67,73	47,07	20,66	80,795	79,299	1,496	6,000	5,500	1,667	1,638
25.12.2024 23	24,00	70,15	48,57	21,58	80,806	79,194	1,613	6,000	5,500	1,742	1,709
26.12.2024 23	24,00	70,08	47,94	22,13	80,284	78,755	1,529	6,000	5,500	1,775	1,743
27.12.2024 23	24,00	72,69	49,14	23,55	80,187	78,804	1,383	6,000	5,500	1,886	1,856
28.12.2024 23	24,00	73,21	49,21	24,00	80,257	78,874	1,383	6,000	5,500	1,924	1,893
29.12.2024 23	24,00	74,78	49,97	24,81	80,383	79,017	1,366	6,000	5,500	1,993	1,961
30.12.2024 23	24,00	72,47	48,75	23,72	79,796	78,424	1,372	6,000	5,500	1,891	1,860
31.12.2024 23	24,00	74,16	49,52	24,64	80,083	78,725	1,359	6,000	5,500	1,972	1,940
01.01.2025 23	24,00	71,33	48,58	22,75	80,101	78,723	1,378	6,000	5,500	1,820	1,791
02.01.2025 23	24,00	69,80	47,90	21,90	80,202	78,810	1,393	6,000	5,500	1,754	1,726
03.01.2025 23	24,00	70,24	48,32	21,92	80,529	79,109	1,420	6,000	5,500	1,763	1,734
04.01.2025 23	24,00	70,03	48,15	21,88	80,160	78,631	1,529	6,000	5,500	1,752	1,721
05.01.2025 23	24,00	72,84	49,03	23,82	79,921	78,351	1,570	6,000	5,500	1,902	1,866
06.01.2025 23	24,00	75,31	50,39	24,92	80,338	78,829	1,509	6,000	5,500	2,000	1,964
07.01.2025 23	24,00	71,61	48,87	22,73	80,213	78,720	1,493	6,000	5,500	1,821	1,789
08.01.2025 23	24,00	72,67	49,24	23,43	79,830	78,332	1,498	6,000	5,500	1,869	1,835
09.01.2025 23	24,00	72,84	49,56	23,28	80,517	79,026	1,490	6,000	5,500	1,873	1,840
10.01.2025 23	24,00	67,50	46,99	20,51	80,454	78,891	1,563	6,000	5,500	1,648	1,618
11.01.2025 23	24,00	70,40	48,48	21,93	80,200	78,639	1,561	6,000	5,500	1,756	1,724
12.01.2025 23	24,00	71,47	48,69	22,79	78,983	77,471	1,512	6,000	5,500	1,798	1,765
13.01.2025 23	24,00	71,20	48,50	22,70	78,972	77,456	1,515	6,000	5,500	1,791	1,758
14.01.2025 23	24,00	74,40	49,57	24,83	78,496	76,839	1,657	6,000	5,500	1,948	1,908
15.01.2025 23	24,00	70,71	47,98	22,73	79,640	77,965	1,675	6,000	5,500	1,809	1,772
16.01.2025 23	24,00	75,05	49,84	25,21	79,383	77,686	1,697	6,000	5,500	2,000	1,958
17.01.2025 23	24,00	73,64	49,34	24,30	79,435	77,811	1,623	6,000	5,500	1,928	1,890
18.01.2025 23	24,00	73,29	49,27	24,02	79,336	77,773	1,563	6,000	5,500	1,904	1,868
19.01.2025 23	24,00	71,27	48,24	23,03	79,263	77,642	1,621	6,000	5,500	1,823	1,788
Среднее	24,00	71,82	48,78	23,04	80,095	78,592	1,503	6,000	5,500	1,843	1,811
Итого	744,00				2482,948	2436,341	46,607			57,146	56,129

Показания счетчиков:

Дата и время	M1, т	M2, т	Q, Гкал
20.12.2024	27464,588	27479,617	651,435
19.01.2025	29947,537	29915,958	708,580

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, д. 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru