

Отчет о потреблении теплоносителя за период с 20.01.2025 по 17.02.2025

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Судоремонтников, д. 64

Тип прибора: TCPB-024M
Номер прибора: 1600694

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгвс, Гкал
20.01.2025 23	24,00	51,21	38,40	12,81	29,400	13,660	15,740	6,363	5,986	15,740	0,828
21.01.2025 23	24,00	50,14	38,63	11,51	31,800	14,340	17,460	6,475	6,057	17,460	0,871
22.01.2025 23	24,00	51,44	39,11	12,33	31,100	14,260	16,840	6,434	6,016	16,840	0,885
23.01.2025 23	24,00	51,33	39,51	11,82	30,400	13,860	16,540	6,312	5,894	16,540	0,847
24.01.2025 23	24,00	52,93	40,18	12,75	30,000	14,440	15,560	6,506	6,067	15,560	0,857
25.01.2025 23	24,00	51,05	39,37	11,68	30,000	13,970	16,030	6,302	5,904	16,030	0,820
26.01.2025 23	24,00	52,91	40,35	12,56	31,800	14,190	17,610	6,322	5,914	17,610	0,933
27.01.2025 23	24,00	50,56	39,47	11,09	31,000	14,160	16,840	6,404	5,986	16,840	0,845
28.01.2025 23	24,00	51,17	38,87	12,30	30,000	14,830	15,170	6,649	6,149	15,170	0,807
29.01.2025 23	24,00	50,13	38,88	11,25	31,600	14,380	17,220	6,475	5,925	17,220	0,851
30.01.2025 23	24,00	52,15	39,59	12,56	30,100	14,580	15,520	6,496	6,057	15,520	0,841
31.01.2025 23	23,98	50,00	38,20	11,80	28,400	13,140	15,260	5,853	5,486	15,260	0,780
01.02.2025 23	24,00	51,02	39,12	11,90	31,000	14,090	16,910	6,618	6,149	16,910	0,861
02.02.2025 23	24,00	50,93	39,30	11,63	32,100	13,790	18,310	6,475	6,016	18,310	0,896
03.02.2025 23	24,00	50,98	38,97	12,01	28,700	13,310	15,390	6,251	5,843	15,390	0,799
04.02.2025 23	24,00	49,81	38,67	11,14	30,100	13,430	16,670	6,220	5,843	16,670	0,826
05.02.2025 23	24,00	51,46	39,21	12,25	31,300	14,240	17,060	6,516	6,108	17,060	0,881
06.02.2025 23	24,00	49,96	38,13	11,83	30,900	13,630	17,270	6,210	5,833	17,270	0,859
07.02.2025 23	24,00	51,60	38,68	12,92	30,000	13,680	16,320	6,200	5,792	16,320	0,861
08.02.2025 23	24,00	50,50	38,20	12,30	30,000	12,670	17,330	5,802	5,354	17,330	0,871
09.02.2025 23	24,00	50,18	37,87	12,31	30,600	13,170	17,430	6,016	5,700	17,430	0,861
10.02.2025 23	24,00	48,59	37,35	11,24	31,900	13,390	18,510	6,159	5,710	18,510	0,877
11.02.2025 23	24,00	50,78	37,92	12,86	31,600	15,460	16,140	5,690	5,455	16,140	0,875
12.02.2025 23	24,00	50,11	40,00	10,11	41,400	21,650	19,750	6,159	5,109	19,750	1,016
13.02.2025 23	24,00	52,26	41,11	11,15	41,700	22,260	19,440	6,169	5,180	19,440	1,067
14.02.2025 23	24,00	51,01	40,14	10,87	40,400	21,280	19,120	6,057	5,078	19,120	1,003
15.02.2025 23	24,00	52,16	40,69	11,47	40,300	21,250	19,050	6,057	4,986	19,050	1,036
16.02.2025 23	24,00	49,42	39,25	10,17	40,500	19,790	20,710	5,802	4,782	20,710	1,018
17.02.2025 23	24,00	51,38	39,98	11,40	40,900	21,780	19,120	6,139	5,099	19,120	1,036
Среднее	24,00	50,94	39,14	11,79	32,317	15,358	17,252	6,246	5,706	17,252	0,890
Итого	695,98				949,000	448,680	500,320			500,320	25,810

Показания счетчиков:

Дата и время	Мтс, т	Wгвс, Гкал
20.01.2025	31987,293	2367,928
17.02.2025	32479,114	2393,738

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru