

Отчет о потреблении теплоносителя за период с 18.02.2025 по 21.03.2025

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Судоремонтников, д. 64

Тип прибора: TCPB-024M
Номер прибора: 1600694

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгвс, Гкал
18.02.2025 23	24,00	49,93	38,98	10,95	39,700	20,560	19,140	5,925	4,925	19,140	0,985
19.02.2025 23	24,00	51,70	40,02	11,68	39,700	20,450	19,250	5,965	4,833	19,250	1,045
20.02.2025 23	24,00	49,08	38,50	10,58	41,500	20,140	21,360	5,904	4,762	21,360	1,042
21.02.2025 23	24,00	50,73	38,60	12,13	39,900	21,300	18,600	6,159	4,935	18,600	1,013
22.02.2025 23	24,00	47,61	36,78	10,83	40,600	19,640	20,960	5,914	4,701	20,960	1,002
23.02.2025 23	24,00	49,55	38,36	11,19	42,100	21,040	21,060	6,179	4,803	21,060	1,077
24.02.2025 23	24,00	49,20	38,15	11,05	40,100	20,380	19,720	6,128	4,772	19,720	0,990
25.02.2025 23	24,00	51,15	38,99	12,16	39,100	20,410	18,690	6,037	4,701	18,690	1,010
26.02.2025 23	24,00	49,76	38,96	10,80	41,900	20,480	21,420	6,057	4,935	21,420	1,064
27.02.2025 23	24,00	51,23	39,53	11,70	40,500	20,200	20,300	5,935	4,742	20,300	1,070
28.02.2025 23	24,00	49,39	38,50	10,89	39,600	19,750	19,850	5,986	4,660	19,850	0,992
01.03.2025 23	24,00	51,31	39,01	12,30	37,500	19,970	17,530	6,128	4,803	17,530	0,965
02.03.2025 23	24,00	50,74	39,82	10,92	40,400	18,950	21,450	5,945	4,680	21,450	1,073
03.03.2025 23	24,00	50,69	39,59	11,10	39,200	19,550	19,650	6,098	4,762	19,650	1,014
04.03.2025 23	24,00	50,76	39,71	11,05	38,800	19,160	19,640	6,067	4,731	19,640	1,009
05.03.2025 23	23,43	51,42	39,77	11,65	37,736	23,085	14,651	6,037	5,109	14,651	0,870
06.03.2025 23	24,00	50,78	40,04	10,74	40,877	26,253	14,624	5,649	5,170	14,624	0,870
07.03.2025 23	23,60	53,37	42,10	11,27	41,077	28,101	12,976	6,098	5,486	12,976	0,873
08.03.2025 23	23,98	50,91	40,16	10,75	39,526	27,315	12,211	5,945	5,303	12,211	0,784
09.03.2025 23	24,00	52,96	41,80	11,16	39,751	27,758	11,993	6,027	5,343	11,993	0,810
10.03.2025 23	24,00	49,88	40,75	9,13	44,189	29,497	14,692	6,353	5,629	14,692	0,853
11.03.2025 23	24,00	52,62	41,83	10,79	40,748	27,127	13,621	5,945	5,262	13,621	0,874
12.03.2025 23	24,00	50,63	40,83	9,80	41,615	27,950	13,665	6,118	5,404	13,665	0,819
13.03.2025 23	24,00	50,17	40,31	9,86	40,234	27,585	12,649	6,057	5,354	12,649	0,779
14.03.2025 23	24,00	48,40	39,39	9,01	39,910	27,234	12,676	6,027	5,323	12,676	0,733
15.03.2025 23	24,00	51,29	40,97	10,32	40,552	27,418	13,134	6,006	5,241	13,134	0,816
16.03.2025 23	24,00	50,11	41,02	9,09	41,560	26,402	15,158	5,976	5,180	15,158	0,835
17.03.2025 23	24,00	50,44	40,95	9,49	40,829	27,704	13,125	6,220	5,354	13,125	0,792
18.03.2025 23	24,00	51,05	41,61	9,44	39,834	26,305	13,529	6,037	5,170	13,529	0,805
19.03.2025 23	24,00	49,21	38,35	10,86	31,403	19,585	11,818	4,731	4,538	11,818	0,735
20.03.2025 23	24,00	50,89	41,02	9,87	39,862	24,963	14,899	5,914	4,966	14,899	0,850
21.03.2025 23	24,00	52,83	41,59	11,24	38,069	25,388	12,681	6,057	5,027	12,681	0,827
Среднее	23,97	50,62	39,87	10,74	39,461	23,308	16,460	5,988	5,019	16,460	0,915
Итого	767,02				1278,377	751,650	526,727			526,727	29,276

Показания счетчиков:

Дата и время	Мтс, т	Wгвс, Гкал
18.02.2025	32479,114	2393,738
21.03.2025	32996,000	2423,014

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
е-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru