

Отчет о потреблении теплоносителя за период с 22.10.2024 по 20.11.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Судоремонтников, д. 64

Тип прибора: TCPB-024M
Номер прибора: 1600694

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t1, °C	t2, °C	dt, °C	V1, м³	V2, м³	Vтс, м³	P1, кг/м³	P2, кг/м³	Vтс, м³	Wгвс, Гкал
22.10.2024 23	24,00	49,52	39,20	10,32	43,500	21,060	22,440	5,721	4,599	22,440	1,102
23.10.2024 23	24,00	35,70	28,25	7,45	13,700	8,250	5,450	2,835	2,488	5,450	0,306
24.10.2024 23	23,78	44,90	35,69	9,21	34,300	15,610	18,690	4,640	3,783	18,690	0,926
25.10.2024 23	24,00	51,03	39,51	11,52	40,100	23,090	17,010	5,680	4,884	17,010	0,964
26.10.2024 23	24,00	50,93	39,69	11,24	41,800	23,530	18,270	5,782	4,976	18,270	1,017
27.10.2024 23	24,00	50,67	39,89	10,78	42,700	23,330	19,370	5,731	4,976	19,370	1,042
28.10.2024 23	24,00	51,73	40,36	11,37	42,400	23,460	18,940	5,761	4,997	18,940	1,046
29.10.2024 23	24,00	49,36	39,55	9,81	43,800	24,090	19,710	5,863	5,037	19,710	1,018
30.10.2024 23	24,00	50,40	39,92	10,48	40,900	23,720	17,180	5,904	5,037	17,180	0,936
31.10.2024 23	24,00	51,17	40,46	10,71	40,600	22,950	17,650	5,710	4,864	17,650	0,959
01.11.2024 23	24,00	49,63	39,80	9,83	42,200	24,940	17,260	6,006	5,078	17,260	0,925
02.11.2024 23	24,00	50,23	40,18	10,05	41,500	25,180	16,320	6,067	5,150	16,320	0,898
03.11.2024 23	24,00	50,58	40,25	10,33	40,800	23,100	17,700	5,629	4,844	17,700	0,951
04.11.2024 23	24,00	50,70	40,83	9,87	45,300	25,340	19,960	5,996	5,109	19,960	1,049
05.11.2024 23	24,00	50,54	39,96	10,58	41,800	24,240	17,560	5,823	4,997	17,560	0,957
06.11.2024 23	24,00	53,81	42,06	11,75	41,700	23,950	17,750	5,772	4,925	17,750	1,042
07.11.2024 23	24,00	52,04	41,28	10,76	41,600	23,720	17,880	5,772	4,915	17,880	0,995
08.11.2024 23	24,00	51,16	40,52	10,64	40,000	22,880	17,120	5,629	4,895	17,120	0,937
09.11.2024 23	23,92	53,38	41,86	11,52	40,800	22,870	17,930	5,670	4,895	17,930	1,032
10.11.2024 23	23,85	53,62	42,26	11,36	41,300	23,470	17,830	5,823	4,935	17,830	1,050
11.11.2024 23	24,00	51,89	41,31	10,58	42,100	22,960	19,140	5,761	4,935	19,140	1,037
12.11.2024 23	24,00	54,07	42,19	11,88	39,300	22,460	16,840	5,751	4,884	16,840	0,993
13.11.2024 23	24,00	56,05	43,81	12,24	42,700	24,720	17,980	6,159	5,180	17,980	1,125
14.11.2024 23	24,00	53,99	42,65	11,34	40,200	22,450	17,750	5,782	4,946	17,750	1,028
15.11.2024 23	24,00	52,69	41,59	11,10	39,200	21,900	17,300	5,690	4,823	17,300	0,961
16.11.2024 23	24,00	54,73	43,08	11,65	41,900	23,700	18,200	5,986	5,017	18,200	1,083
17.11.2024 23	24,00	52,64	41,60	11,04	41,600	23,270	18,330	5,874	4,997	18,330	1,029
18.11.2024 23	24,00	53,63	42,15	11,48	40,900	23,010	17,890	5,782	4,946	17,890	1,035
19.11.2024 23	24,00	55,06	43,59	11,47	42,100	23,930	18,170	5,976	5,027	18,170	1,084
20.11.2024 23	24,00	53,00	42,46	10,54	41,000	22,960	18,040	5,792	4,935	18,040	1,008
Среднее	23,99	51,30	40,53	10,76	39,876	22,489	17,722	5,679	4,836	17,722	0,985
Итого	719,55				1211,800	680,140	531,661			531,661	29,535

Показания счетчиков:

Дата и время	Мтс, т	Wгвс, Гкал
22.10.2024	30438,511	2282,469
20.11.2024	30960,137	2312,004

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru