

Отчет о потреблении тепловой энергии и теплоносителя за период с 20.12.2024 по 19.01.2025

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Таманская, д. 22

Тип прибора: СПТ944
Номер прибора: 11798

Дата	Теплосистема 1 - отопление									Теплота (Гкал) Qпод	Теплота (Гкал) Qобр
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, кг/м³	P2, кг/м³		
20.12.2024 23	24,00	61,27	40,60	20,67	87,528	86,552	0,976	6,000	5,500	1,808	1,789
21.12.2024 23	24,00	58,12	39,45	18,66	87,625	86,645	0,981	6,000	5,500	1,634	1,617
22.12.2024 23	24,00	58,21	39,58	18,63	82,040	81,651	0,389	6,000	5,500	1,537	1,521
23.12.2024 23	24,00	59,75	40,61	19,15	89,251	88,027	1,224	6,000	5,500	1,704	1,685
24.12.2024 23	24,00	58,49	42,20	16,29	105,023	103,760	1,262	6,000	5,500	1,707	1,690
25.12.2024 23	24,00	57,34	39,66	17,69	89,254	88,137	1,117	6,000	5,500	1,577	1,559
26.12.2024 23	24,00	59,38	40,40	18,98	89,224	88,121	1,104	6,000	5,500	1,693	1,673
27.12.2024 23	24,00	57,00	39,24	17,76	89,914	88,767	1,146	6,000	5,500	1,594	1,577
28.12.2024 23	24,00	57,06	38,62	18,43	88,253	87,172	1,081	6,000	5,500	1,623	1,607
29.12.2024 23	24,00	57,64	38,87	18,77	88,134	87,061	1,073	6,000	5,500	1,651	1,634
30.12.2024 23	24,00	57,75	39,02	18,73	88,109	87,045	1,064	6,000	5,500	1,647	1,630
31.12.2024 23	24,00	56,40	38,52	17,89	88,169	87,102	1,067	6,000	5,500	1,574	1,558
01.01.2025 23	24,00	57,15	39,00	18,15	88,169	87,094	1,076	6,000	5,500	1,599	1,581
02.01.2025 23	24,00	56,36	38,64	17,72	88,121	87,042	1,080	6,000	5,500	1,560	1,542
03.01.2025 23	24,00	56,14	38,64	17,50	87,854	86,785	1,069	6,000	5,500	1,537	1,519
04.01.2025 23	24,00	58,21	39,23	18,98	87,623	86,565	1,057	6,000	5,500	1,652	1,643
05.01.2025 23	24,00	61,59	40,58	21,01	87,406	86,386	1,021	6,000	5,500	1,834	1,815
06.01.2025 23	24,00	56,34	38,54	17,81	87,821	86,782	1,039	6,000	5,500	1,562	1,545
07.01.2025 23	24,00	56,39	38,48	17,91	87,567	86,522	1,045	6,000	5,500	1,565	1,550
08.01.2025 23	24,00	56,22	38,48	17,75	87,885	86,782	1,103	6,000	5,500	1,556	1,540
09.01.2025 23	24,00	56,20	38,52	17,68	87,790	86,747	1,044	6,000	5,500	1,549	1,533
10.01.2025 23	24,00	56,16	38,61	17,55	87,668	86,626	1,042	6,000	5,500	1,535	1,520
11.01.2025 23	24,00	56,29	38,61	17,67	87,597	86,563	1,034	6,000	5,500	1,545	1,530
12.01.2025 23	24,00	55,98	38,63	17,35	87,755	86,704	1,051	6,000	5,500	1,521	1,504
13.01.2025 23	24,00	57,09	38,68	18,41	87,502	86,466	1,036	6,000	5,500	1,603	1,591
14.01.2025 23	24,00	57,10	38,61	18,49	87,516	86,486	1,030	6,000	5,500	1,615	1,599
15.01.2025 23	24,00	57,81	38,80	19,01	87,567	86,544	1,022	6,000	5,500	1,660	1,645
16.01.2025 23	24,00	57,95	38,80	19,15	87,545	86,515	1,030	6,000	5,500	1,670	1,657
17.01.2025 23	24,00	55,91	37,99	17,92	87,387	86,368	1,020	6,000	5,500	1,565	1,548
18.01.2025 23	24,00	55,29	37,65	17,64	87,426	86,408	1,018	6,000	5,500	1,539	1,524
19.01.2025 23	24,00	58,19	38,97	19,22	87,720	86,723	0,998	6,000	5,500	1,684	1,667
Среднее	24,00	57,44	39,10	18,34	88,337	87,295	1,042	6,000	5,500	1,616	1,600
Итого	744,00				2738,444	2706,147	32,297			50,100	49,594

Показания счетчиков:

Дата и время	M1, т	M2, т	Q, Гкал
20.12.2024	26780,452	26614,954	452,359
19.01.2025	29518,896	29321,102	502,459

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, д. 11 блок 2
е-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46

Подготовлен программным комплексом «Взлет СП». www.vzljot.ru