

Отчет о потреблении теплоносителя за период с 20.12.2024 по 19.01.2025

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Фрунзе, д. 5

Тип прибора: ТСРВ-042
Номер прибора: 1600874

Дата	Теплосистема 1 - отопление									Теплота (Гкал) Qпод	Теплота (Гкал) Qобр
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, кг/м³	P2, кг/м³		
20.12.2024 23	24,00	62,41	40,06	22,35	161,767	157,214	4,553	8,882	5,517	3,620	3,514
21.12.2024 23	24,00	61,16	39,98	21,18	161,953	157,390	4,563	8,923	5,517	3,435	3,334
22.12.2024 23	24,00	58,10	39,01	19,09	162,716	158,209	4,507	8,719	5,517	3,111	3,022
23.12.2024 23	24,00	58,42	39,63	18,79	168,305	163,612	4,693	8,749	5,517	3,163	3,071
24.12.2024 23	24,00	59,66	40,40	19,26	168,483	163,740	4,743	8,974	5,517	3,247	3,150
25.12.2024 23	20,45	51,09	36,69	14,40	122,445	118,683	3,763	7,434	5,517	2,277	2,198
26.12.2024 23	24,00	57,64	39,24	18,40	166,679	161,697	4,982	8,810	5,517	3,073	2,977
27.12.2024 23	24,00	59,31	39,95	19,36	166,620	161,710	4,910	8,800	5,517	3,230	3,129
28.12.2024 23	24,00	56,68	38,60	18,08	165,919	161,143	4,776	8,402	5,517	3,001	2,912
29.12.2024 23	24,00	57,43	38,45	18,98	166,003	160,985	5,018	8,606	5,517	3,155	3,055
30.12.2024 23	24,00	57,84	38,61	19,23	166,319	161,229	5,090	8,719	5,517	3,203	3,100
31.12.2024 23	24,00	57,79	38,69	19,10	166,451	161,520	4,930	8,657	5,517	3,184	3,085
01.01.2025 23	24,00	56,63	38,26	18,37	166,564	161,650	4,915	8,810	5,517	3,065	2,970
02.01.2025 23	24,00	57,22	38,70	18,52	166,619	161,680	4,939	8,790	5,517	3,091	2,994
03.01.2025 23	24,00	56,53	38,52	18,01	166,702	161,753	4,949	8,800	5,517	3,007	2,913
04.01.2025 23	24,00	55,95	38,35	17,60	166,808	161,872	4,936	8,780	5,517	2,941	2,849
05.01.2025 23	24,00	58,96	39,14	19,82	166,386	161,357	5,028	8,780	5,517	3,303	3,198
06.01.2025 23	24,00	61,24	40,04	21,20	166,287	161,198	5,089	8,749	5,517	3,528	3,417
07.01.2025 23	24,00	56,46	38,33	18,13	166,529	161,613	4,916	8,749	5,517	3,024	2,930
08.01.2025 23	24,00	56,54	38,39	18,15	166,485	161,562	4,922	8,698	5,517	3,028	2,934
09.01.2025 23	24,00	56,45	38,47	17,98	166,600	161,672	4,928	8,729	5,517	3,000	2,905
10.01.2025 23	24,00	56,39	38,71	17,68	168,186	163,224	4,961	8,749	5,517	2,977	2,884
11.01.2025 23	24,00	56,36	38,75	17,61	166,753	161,838	4,914	8,739	5,517	2,942	2,848
12.01.2025 23	24,00	56,47	38,76	17,71	166,872	161,931	4,940	8,678	5,517	2,960	2,868
13.01.2025 23	24,00	56,05	38,65	17,40	166,922	162,015	4,907	8,719	5,517	2,910	2,821
14.01.2025 23	24,00	57,30	38,53	18,77	166,364	161,492	4,873	8,729	5,517	3,127	3,031
15.01.2025 23	24,00	57,30	38,55	18,75	166,430	161,532	4,897	8,729	5,517	3,125	3,029
16.01.2025 23	24,00	57,89	38,50	19,39	166,396	161,470	4,925	8,708	5,517	3,231	3,131
17.01.2025 23	24,00	57,95	38,49	19,46	166,076	160,429	5,647	8,729	5,517	3,238	3,124
18.01.2025 23	24,00	55,90	37,66	18,24	166,667	161,844	4,823	8,800	5,517	3,044	2,950
19.01.2025 23	24,00	55,71	37,46	18,25	166,612	161,806	4,805	8,780	5,517	3,045	2,953
Среднее	23,89	57,45	38,76	18,69	164,836	159,970	4,866	8,707	5,517	3,106	3,010
Итого	740,45				5109,915	4959,071	150,844			96,284	93,297

Показания счетчиков:

Дата и время	M1, т	M2, т	Qтс, Гкал
20.12.2024	57129,353	55745,612	1007,107
19.01.2025	62239,268	60704,684	1103,391

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru