

Отчет о потреблении теплоносителя за период с 20.01.2025 по 17.02.2025

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Фрунзе, д. 22

Тип прибора: ТСРВ-042
Номер прибора: 1600929

Дата	Теплосистема 1 - отопление									Теплота (Гкал) Qпод	Теплота (Гкал) Qобр
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, кг/м³	P2, кг/м³		
20.01.2025 23	24,00	57,59	36,71	20,88	61,274	63,681	-2,408	6,118	5,608	1,277	1,328
21.01.2025 23	24,00	57,32	35,34	21,98	55,600	57,447	-1,847	6,118	5,608	1,215	1,257
22.01.2025 23	24,00	57,63	35,21	22,42	54,419	56,001	-1,581	6,118	5,608	1,218	1,256
23.01.2025 23	24,00	52,51	34,88	17,63	44,137	50,008	-5,871	6,118	5,608	0,972	1,072
24.01.2025 23	24,00	56,38	34,83	21,55	54,543	58,096	-3,553	6,118	5,608	1,173	1,251
25.01.2025 23	24,00	58,15	36,23	21,92	57,967	62,161	-4,194	6,118	5,608	1,270	1,363
26.01.2025 23	24,00	56,50	35,53	20,97	55,886	59,791	-3,904	6,118	5,608	1,172	1,255
27.01.2025 23	24,00	57,74	35,37	22,37	54,535	58,254	-3,719	6,118	5,608	1,218	1,303
28.01.2025 23	24,00	58,28	35,74	22,54	55,444	59,161	-3,716	6,118	5,608	1,248	1,333
29.01.2025 23	24,00	59,63	36,02	23,61	54,904	57,347	-2,443	6,118	5,608	1,295	1,355
30.01.2025 23	24,00	58,42	36,01	22,41	55,853	57,306	-1,453	6,118	5,608	1,249	1,284
31.01.2025 23	24,00	57,14	35,51	21,63	55,358	56,850	-1,491	6,118	5,608	1,196	1,230
01.02.2025 23	24,00	56,69	35,48	21,21	55,273	56,751	-1,478	6,118	5,608	1,171	1,204
02.02.2025 23	24,00	55,28	35,13	20,15	54,927	56,123	-1,196	6,118	5,608	1,105	1,130
03.02.2025 23	24,00	55,48	35,21	20,27	55,208	56,209	-1,002	6,118	5,608	1,117	1,139
04.02.2025 23	24,00	55,67	34,93	20,74	55,074	56,076	-1,002	6,118	5,608	1,141	1,163
05.02.2025 23	24,00	59,78	35,91	23,87	55,046	56,046	-1,000	6,118	5,608	1,312	1,338
06.02.2025 23	24,00	57,13	34,78	22,35	54,935	56,009	-1,073	6,118	5,608	1,226	1,252
07.02.2025 23	24,00	57,95	34,30	23,65	52,891	53,951	-1,060	6,118	5,608	1,253	1,280
08.02.2025 23	24,00	59,94	35,18	24,76	55,072	56,130	-1,059	6,118	5,608	1,362	1,390
09.02.2025 23	24,00	60,98	35,39	25,59	55,090	56,146	-1,056	6,118	5,608	1,408	1,437
10.02.2025 23	24,00	59,95	35,38	24,57	55,514	56,812	-1,298	6,118	5,608	1,362	1,396
11.02.2025 23	24,00	53,47	33,42	20,05	49,465	50,924	-1,459	6,118	5,608	1,070	1,104
12.02.2025 23	24,00	57,42	35,48	21,94	58,147	59,981	-1,834	6,118	5,608	1,274	1,316
13.02.2025 23	24,00	58,13	36,12	22,01	58,392	60,286	-1,894	6,118	5,608	1,282	1,326
14.02.2025 23	24,00	55,96	35,41	20,55	58,131	60,092	-1,961	6,118	5,608	1,193	1,235
15.02.2025 23	24,00	54,62	34,97	19,65	57,824	59,714	-1,890	6,118	5,608	1,136	1,173
16.02.2025 23	24,00	54,57	34,71	19,86	57,795	59,958	-2,163	6,118	5,608	1,147	1,191
17.02.2025 23	24,00	62,90	37,11	25,79	58,118	60,324	-2,206	6,118	5,608	1,497	1,555
Среднее	24,00	57,35	35,39	21,96	55,408	57,505	-2,097	6,118	5,608	1,226	1,273
Итого	696,00				1606,821	1667,634	-60,813			35,557	36,917

Показания счетчиков:

Дата и время	M1, т	M2, т	Qтс, Гкал
20.01.2025	33742,196	29460,300	652,463
17.02.2025	35349,017	31127,934	688,020

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru