

Отчет о потреблении тепловой энергии и теплоносителя за период с 12.07.2024 по 11.08.2024

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Фрунзе, д. 63

Тип прибора: СПТ941.20
Номер прибора: 82195

Дата	Теплосистема 1 - отопление									Теплота (Гкал) Qпод	Теплота (Гкал) Qобр
	ВР, ч	t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, кг/м³	P2, кг/м³		
20.12.2024 23	24,00	59,46	40,21	19,25	96,340	96,954	-0,614	6,000	5,500	1,852	1,866
21.12.2024 23	24,00	61,55	40,93	20,63	93,660	94,347	-0,688	6,000	5,500	1,929	1,946
22.12.2024 23	24,00	58,80	40,26	18,54	95,851	96,555	-0,704	6,000	5,500	1,774	1,790
23.12.2024 23	24,00	56,08	39,22	16,86	95,756	96,593	-0,837	6,000	5,500	1,612	1,629
24.12.2024 23	24,00	57,00	39,42	17,58	91,694	92,515	-0,821	6,000	5,500	1,610	1,626
25.12.2024 23	24,00	56,45	38,96	17,49	71,963	72,772	-0,808	6,000	5,500	1,257	1,273
26.12.2024 23	24,00	57,88	40,02	17,86	91,772	92,892	-1,120	6,000	5,500	1,636	1,659
27.12.2024 23	24,00	59,16	40,05	19,11	90,727	91,898	-1,171	6,000	5,500	1,731	1,756
28.12.2024 23	24,00	59,25	40,02	19,23	90,556	91,602	-1,046	6,000	5,500	1,739	1,761
29.12.2024 23	24,00	56,85	38,74	18,11	91,103	92,439	-1,336	6,000	5,500	1,648	1,674
30.12.2024 23	24,00	59,00	39,52	19,49	90,686	92,116	-1,430	6,000	5,500	1,765	1,795
31.12.2024 23	24,00	59,19	39,99	19,20	93,245	94,679	-1,435	6,000	5,500	1,788	1,818
01.01.2025 23	24,00	58,69	40,09	18,60	94,390	95,966	-1,576	6,000	5,500	1,753	1,785
02.01.2025 23	24,00	58,83	40,24	18,59	94,689	96,258	-1,569	6,000	5,500	1,758	1,790
03.01.2025 23	24,00	58,30	40,17	18,13	94,705	96,261	-1,556	6,000	5,500	1,715	1,745
04.01.2025 23	24,00	58,50	40,38	18,11	94,804	96,451	-1,647	6,000	5,500	1,715	1,747
05.01.2025 23	24,00	57,14	39,64	17,50	94,336	95,982	-1,646	6,000	5,500	1,648	1,680
06.01.2025 23	24,00	62,55	41,60	20,95	95,248	96,901	-1,653	6,000	5,500	1,993	2,031
07.01.2025 23	24,00	60,04	40,77	19,27	95,255	96,833	-1,578	6,000	5,500	1,833	1,866
08.01.2025 23	24,00	57,87	39,84	18,03	95,139	96,868	-1,729	6,000	5,500	1,713	1,746
09.01.2025 23	24,00	57,65	39,98	17,67	95,977	97,756	-1,779	6,000	5,500	1,694	1,728
10.01.2025 23	24,00	58,20	40,31	17,88	97,023	98,935	-1,911	6,000	5,500	1,733	1,769
11.01.2025 23	24,00	58,16	40,68	17,49	98,718	100,508	-1,790	6,000	5,500	1,724	1,758
12.01.2025 23	24,00	58,26	40,71	17,55	97,906	99,812	-1,906	6,000	5,500	1,716	1,751
13.01.2025 23	24,00	58,01	40,39	17,61	96,078	98,039	-1,961	6,000	5,500	1,690	1,727
14.01.2025 23	24,00	58,63	40,62	18,01	97,198	99,121	-1,924	6,000	5,500	1,748	1,785
15.01.2025 23	24,00	59,22	40,52	18,70	96,342	98,133	-1,791	6,000	5,500	1,799	1,835
16.01.2025 23	24,00	59,56	40,59	18,97	96,109	98,031	-1,922	6,000	5,500	1,820	1,860
17.01.2025 23	24,00	60,05	40,60	19,46	95,916	97,733	-1,817	6,000	5,500	1,863	1,902
18.01.2025 23	24,00	58,68	40,01	18,67	95,582	97,557	-1,975	6,000	5,500	1,782	1,822
19.01.2025 23	24,00	56,78	39,46	17,32	97,773	99,860	-2,087	6,000	5,500	1,691	1,730
Среднее	24,00	58,57	40,13	18,45	94,082	95,560	-1,478	6,000	5,500	1,733	1,763
Итого	744,00				2916,541	2962,367	-45,826			53,727	54,649

Показания счетчиков:

Дата и время	M1, т	M2, т	Q, Гкал
20.12.2024	51377,486	46098,755	865,197
19.01.2025	54294,027	49061,122	918,924

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, д. 11 блок 2
е-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru