

Отчет о потреблении тепловой энергии и теплоносителя с 21.03.2026 по 20.04.2026

Прибор Прибор: КАРАТ-307 (16993716)
Потребитель УК "ЖКС"
Адрес узла г. Туапсе, ул. Комсомольская, д. 19 блок 1

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1	
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, МПа	P2, МПа	Qпод, Гкал	Qобр, Гкал
21.03.2026	24.00	58.87	27.69	31.18	12.728	13.152	(0.424)	0.41	0.41	0.411	0.430
22.03.2026	24.00	62.60	28.79	33.81	14.069	14.800	(0.730)	0.45	0.45	0.475	0.500
23.03.2026	24.00	65.56	28.96	36.61	13.966	14.717	(0.750)	0.45	0.45	0.511	0.538
24.03.2026	24.00	65.25	28.74	36.52	14.031	14.712	(0.681)	0.45	0.45	0.512	0.537
25.03.2026	24.00	66.14	30.91	35.23	19.851	20.646	(0.795)	0.44	0.44	0.671	0.699
26.03.2026	24.00	67.47	38.76	28.72	36.229	37.364	(1.135)	0.44	0.42	1.040	1.072
27.03.2026	24.00	68.17	39.55	28.62	36.334	37.487	(1.153)	0.44	0.42	1.039	1.072
28.03.2026	24.00	67.53	39.87	27.67	36.884	38.046	(1.162)	0.44	0.42	1.019	1.051
29.03.2026	24.00	66.25	39.50	26.75	36.392	37.576	(1.184)	0.44	0.42	0.973	1.004
30.03.2026	24.00	67.36	39.58	27.77	34.840	35.952	(1.112)	0.44	0.42	0.963	0.994
31.03.2026	24.00	67.51	36.68	30.83	27.582	28.530	(0.948)	0.47	0.45	0.850	0.879
01.04.2026	24.00	65.56	36.58	28.98	28.392	29.384	(0.992)	0.48	0.46	0.821	0.849
02.04.2026	24.00	64.24	36.32	27.92	28.113	29.115	(1.003)	0.47	0.46	0.784	0.812
03.04.2026	24.00	63.78	36.54	27.24	27.857	28.875	(1.018)	0.47	0.46	0.758	0.785
04.04.2026	24.00	65.53	36.30	29.23	27.574	28.542	(0.969)	0.47	0.45	0.806	0.834
05.04.2026	24.00	67.41	37.04	30.38	27.648	28.598	(0.950)	0.47	0.45	0.839	0.868
06.04.2026	24.00	65.74	36.73	29.01	27.846	28.834	(0.988)	0.47	0.46	0.807	0.835
07.04.2026	24.00	66.14	34.46	31.68	22.946	23.905	(0.959)	0.47	0.47	0.726	0.757
08.04.2026	24.00	67.26	33.76	33.50	22.905	23.813	(0.908)	0.47	0.47	0.767	0.797
09.04.2026	24.00	69.16	35.31	33.85	28.903	29.906	(1.003)	0.47	0.45	0.937	0.970
10.04.2026	24.00	70.69	46.58	24.11	59.258	60.788	(1.530)	0.46	0.39	1.429	1.466
11.04.2026	24.00	69.52	43.49	26.03	46.379	47.622	(1.243)	0.47	0.42	1.192	1.224
12.04.2026	24.00	67.70	40.18	27.52	36.811	37.878	(1.066)	0.47	0.44	1.013	1.042
13.04.2026	24.00	63.22	38.97	24.25	34.631	35.647	(1.017)	0.45	0.42	0.900	0.926
14.04.2026	24.00	66.90	39.52	27.38	36.074	37.171	(1.097)	0.46	0.44	0.989	1.019
15.04.2026	24.00	67.28	39.94	27.34	36.329	37.443	(1.114)	0.46	0.44	0.993	1.023
16.04.2026	24.00	46.17	31.93	14.24	22.312	22.793	(0.481)	0.35	0.34	0.463	0.478
17.04.2026	24.00	36.52	25.16	11.37	1.213	1.458	(0.246)	0.34	0.35	0.036	0.044
18.04.2026	24.00	20.98	20.40	0.58	0.000	0.000	0.000	0.25	0.25	0.000	0.000
19.04.2026	24.00	20.08	19.30	0.78	0.000	0.000	0.000	0.24	0.24	0.000	0.000
Среднее	24.00	61.55	34.92	26.64	26.603	27.492	(0.889)	0.44	0.42	0.757	0.784
Итого	720.00				798.095	824.755	(26.660)			22.723	23.505

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11/2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46