

Отчет о потреблении тепловой энергии за период с 21.10.2025 по 20.11.2025

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Кириченко, д. 4А

Тип прибора: БКТ-7
Номер прибора: 74026

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
21.10.2025	24,00	53,29	47,13	6,16	21,650	19,050	2,600	4,000	3,500	2,600	0,227
22.10.2025	24,00	55,10	48,66	6,44	21,770	19,050	2,720	4,000	3,500	2,720	0,240
23.10.2025	24,00	54,10	48,02	6,08	21,010	19,100	1,910	4,000	3,500	1,910	0,195
24.10.2025	24,00	55,91	49,50	6,41	21,240	19,180	2,060	4,000	3,500	2,060	0,215
25.10.2025	24,00	53,81	47,47	6,34	21,280	19,140	2,140	4,000	3,500	2,140	0,213
26.10.2025	25,00	54,23	48,29	5,94	22,260	18,050	4,210	4,000	3,500	4,210	0,292
27.10.2025	24,00	53,66	47,71	5,95	21,490	19,010	2,480	4,000	3,500	2,480	0,222
28.10.2025	24,00	52,79	47,12	5,67	21,870	18,910	2,960	4,000	3,500	2,960	0,233
29.10.2025	24,00	54,77	48,72	6,05	21,620	18,930	2,690	4,000	3,500	2,690	0,230
30.10.2025	24,00	53,97	47,72	6,25	22,080	18,830	3,250	4,000	3,500	3,250	0,258
31.10.2025	24,00	53,79	47,71	6,08	21,350	18,950	2,400	4,000	3,500	2,400	0,221
01.11.2025	24,00	53,77	47,60	6,17	21,710	18,970	2,740	4,000	3,500	2,740	0,232
02.11.2025	24,00	54,21	48,01	6,20	22,740	18,960	3,780	4,000	3,500	3,780	0,281
03.11.2025	24,00	54,53	48,15	6,38	22,150	18,920	3,230	4,000	3,500	3,230	0,261
04.11.2025	24,00	54,10	47,65	6,45	22,950	18,900	4,050	4,000	3,500	4,050	0,295
05.11.2025	24,00	54,52	48,28	6,24	21,340	19,010	2,330	4,000	3,500	2,330	0,218
06.11.2025	24,00	52,75	46,76	5,99	21,410	18,950	2,460	4,000	3,500	2,460	0,216
07.11.2025	24,00	54,35	48,17	6,18	21,340	18,970	2,370	4,000	3,500	2,370	0,220
08.11.2025	24,00	54,06	47,85	6,21	21,310	19,040	2,270	4,000	3,500	2,270	0,215
09.11.2025	24,00	53,07	47,11	5,96	22,660	18,880	3,780	4,000	3,500	3,780	0,273
10.11.2025	24,00	55,26	48,94	6,32	21,470	18,920	2,550	4,000	3,500	2,550	0,230
11.11.2025	24,00	55,49	48,92	6,57	19,310	17,000	2,310	4,000	3,500	2,310	0,213
12.11.2025	24,00	52,13	46,46	5,67	22,320	18,860	3,460	4,000	3,500	3,460	0,250
13.11.2025	24,00	55,85	49,35	6,50	21,280	18,250	3,030	4,000	3,500	3,030	0,254
14.11.2025	24,00	53,15	47,13	6,02	22,320	18,900	3,420	4,000	3,500	3,420	0,259
15.11.2025	24,00	55,75	49,11	6,64	22,030	18,930	3,100	4,000	3,500	3,100	0,261
16.11.2025	24,00	54,08	47,87	6,21	22,770	18,850	3,920	4,000	3,500	3,920	0,287
17.11.2025	24,00	55,82	49,38	6,44	21,290	18,900	2,390	4,000	3,500	2,390	0,229
18.11.2025	24,00	55,32	48,97	6,35	21,660	18,910	2,750	4,000	3,500	2,750	0,242
19.11.2025	24,00	54,89	48,63	6,26	21,440	18,860	2,580	4,000	3,500	2,580	0,231
20.11.2025	24,00	54,23	47,94	6,29	21,590	19,020	2,570	4,000	3,500	2,570	0,229
Среднее	24,03	54,28	48,08	6,21	21,700	18,845	2,855	4,000	3,500	2,855	0,240
Итого	745,00				672,710	584,200	88,510			88,510	7,442

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru