

Отчет о потреблении тепловой энергии и теплоносителя с 21.11.2025 по 20.12.2025

Прибор: КАРАТ-307 (09913016)
Потребитель: Жилой дом
Адрес узла: г. Туапсе, ул. Калараша, д. 33 блок 3

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1	
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, МПа	P2, МПа	Qпод, Гкал	Qобр, Гкал
21.11.2025	24.00	51.69	45.22	6.47	113.629	113.956	(0.328)	6.00	5.50	0.730	0.732
22.11.2025	24.00	47.64	40.56	7.07	78.730	78.883	(0.153)	6.00	5.50	0.557	0.558
23.11.2025	24.00	46.75	40.20	6.55	73.940	74.079	(0.139)	6.00	5.50	0.485	0.486
24.11.2025	24.00	47.04	40.20	6.84	74.335	74.595	(0.260)	6.00	5.50	0.509	0.511
25.11.2025	24.00	46.64	39.23	7.41	77.805	78.964	(1.159)	6.00	5.50	0.577	0.585
26.11.2025	24.00	44.75	37.63	7.12	64.360	65.534	(1.174)	6.00	5.50	0.459	0.467
27.11.2025	24.00	44.72	37.36	7.37	64.900	66.042	(1.143)	6.00	5.50	0.481	0.489
28.11.2025	24.00	44.87	36.95	7.91	71.764	73.409	(1.646)	6.00	5.50	0.568	0.581
29.11.2025	24.00	45.28	37.62	7.66	73.917	75.657	(1.741)	6.00	5.50	0.568	0.582
30.11.2025	24.00	44.93	36.95	7.98	76.810	78.615	(1.805)	6.00	5.50	0.613	0.627
01.12.2025	24.00	44.07	36.41	7.65	74.159	75.781	(1.623)	6.00	5.50	0.567	0.580
02.12.2025	24.00	45.46	37.09	8.37	68.000	69.489	(1.490)	6.00	5.50	0.570	0.583
03.12.2025	24.00	47.56	38.29	9.27	72.982	74.791	(1.809)	6.00	5.50	0.677	0.694
04.12.2025	24.00	46.67	37.29	9.38	69.688	71.324	(1.637)	6.00	5.50	0.654	0.669
05.12.2025	24.00	46.33	37.02	9.31	70.728	72.324	(1.596)	6.00	5.50	0.658	0.673
06.12.2025	24.00	46.42	37.08	9.34	71.892	73.237	(1.345)	6.00	5.50	0.671	0.684
07.12.2025	24.00	48.02	37.85	10.17	70.229	71.645	(1.417)	6.00	5.50	0.713	0.728
08.12.2025	24.00	52.19	40.89	11.30	72.001	73.610	(1.608)	6.00	5.50	0.813	0.831
09.12.2025	24.00	52.00	41.01	10.99	73.650	75.355	(1.705)	6.00	5.50	0.809	0.828
10.12.2025	24.00	52.18	41.71	10.48	80.417	82.572	(2.155)	6.00	5.50	0.839	0.861
11.12.2025	24.00	52.57	42.79	9.79	89.445	91.950	(2.505)	6.00	5.50	0.876	0.900
12.12.2025	24.00	53.68	43.83	9.85	93.990	96.425	(2.435)	6.00	5.50	0.926	0.950
13.12.2025	24.00	53.39	41.01	12.38	70.008	71.324	(1.316)	6.00	5.50	0.866	0.883
14.12.2025	24.00	63.13	45.87	17.26	69.259	70.511	(1.252)	6.00	5.50	1.197	1.218
15.12.2025	24.00	60.20	44.31	15.89	68.728	69.966	(1.238)	6.00	5.50	1.092	1.112
16.12.2025	24.00	57.60	42.53	15.08	67.595	68.774	(1.179)	6.00	5.50	1.019	1.037
17.12.2025	24.00	58.25	43.30	14.95	68.800	70.008	(1.208)	6.00	5.50	1.026	1.044
18.12.2025	24.00	53.73	40.78	12.95	68.023	69.160	(1.137)	6.00	5.50	0.880	0.895
19.12.2025	24.00	52.79	40.56	12.23	69.040	70.167	(1.126)	6.00	5.50	0.845	0.858
20.12.2025	24.00	52.13	39.85	12.28	67.398	68.432	(1.034)	6.00	5.50	0.827	0.840
Среднее	24.00	50.09	40.05	10.04	74.207	75.553	(1.345)	6.00	5.50	0.736	0.750
Итого	720.00				2,226.220	2,266.579	(40.359)			22.074	22.487

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11/2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46