

Отчет о потреблении тепловой энергии и теплоносителя с 21.11.2025 по 20.12.2025

Прибор: КАРАТ-307 (10123016)
Потребитель: Жилой дом
Адрес узла: г. Туапсе, ул. Б. Хмельницкого, 5

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1	
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, МПа	P2, МПа	Qпод, Гкал	Qобр, Гкал
21.11.2025	24.00	16.27	15.76	0.51	0.000	0.000	0.000	0.01	0.52	0.000	0.000
22.11.2025	24.00	15.76	15.19	0.58	0.000	0.000	0.000	0.01	0.52	0.000	0.000
23.11.2025	24.00	16.09	15.63	0.46	0.000	0.000	0.000	0.01	0.52	0.000	0.000
24.11.2025	24.00	15.98	15.52	0.46	0.000	0.000	0.000	0.01	0.52	0.000	0.000
25.11.2025	24.00	18.08	18.93	(0.85)	0.000	0.003	(0.003)	0.08	0.52	0.000	0.000
26.11.2025	24.00	26.75	21.79	4.97	9.391	8.690	0.701	0.29	0.52	0.217	0.201
27.11.2025	24.00	65.56	44.46	21.10	41.635	40.261	1.374	0.69	0.53	0.879	0.850
28.11.2025	24.00	61.17	42.36	18.81	41.058	39.412	1.645	0.69	0.52	0.773	0.742
29.11.2025	24.00	64.11	43.91	20.20	40.751	39.209	1.542	0.66	0.53	0.823	0.792
30.11.2025	24.00	60.13	41.99	18.14	39.842	38.255	1.587	0.66	0.53	0.724	0.695
01.12.2025	24.00	54.22	39.84	14.37	36.632	35.247	1.385	0.67	0.52	0.586	0.564
02.12.2025	24.00	50.48	36.94	13.54	37.926	36.406	1.521	0.73	0.52	0.514	0.494
03.12.2025	24.00	56.19	39.24	16.95	37.027	35.475	1.551	0.67	0.52	0.628	0.602
04.12.2025	24.00	59.48	40.47	19.00	36.670	35.154	1.516	0.67	0.52	0.696	0.668
05.12.2025	24.00	68.69	44.83	23.85	37.045	35.848	1.197	0.64	0.53	0.883	0.856
06.12.2025	24.00	71.06	46.03	25.03	37.004	35.989	1.015	0.69	0.53	0.927	0.902
07.12.2025	24.00	70.15	45.64	24.50	36.970	35.776	1.194	0.69	0.53	0.907	0.877
08.12.2025	24.00	66.34	44.33	22.01	37.861	36.602	1.259	0.69	0.53	0.840	0.813
09.12.2025	24.00	67.77	45.13	22.64	37.843	36.550	1.293	0.66	0.53	0.857	0.828
10.12.2025	24.00	71.11	46.84	24.26	38.366	37.225	1.141	0.67	0.52	0.931	0.904
11.12.2025	24.00	69.92	46.24	23.67	38.627	37.492	1.134	0.66	0.53	0.915	0.888
12.12.2025	24.00	72.19	47.14	25.05	38.401	37.337	1.064	0.68	0.53	0.963	0.936
13.12.2025	24.00	70.21	46.21	24.00	38.511	37.341	1.169	0.68	0.53	0.925	0.897
14.12.2025	24.00	73.40	46.69	26.71	38.106	37.064	1.042	0.68	0.52	1.019	0.991
15.12.2025	24.00	72.97	46.55	26.41	37.637	36.615	1.022	0.67	0.52	0.995	0.968
16.12.2025	24.00	73.83	46.50	27.32	36.938	35.941	0.998	0.67	0.52	1.010	0.983
17.12.2025	24.00	69.02	44.39	24.63	36.812	35.698	1.115	0.67	0.52	0.906	0.879
18.12.2025	24.00	72.70	46.07	26.62	36.503	35.469	1.034	0.71	0.53	0.973	0.945
19.12.2025	24.00	72.51	46.59	25.92	36.840	35.691	1.149	0.69	0.53	0.956	0.926
20.12.2025	24.00	72.11	46.37	25.73	37.231	36.200	1.031	0.67	0.53	0.959	0.932
Среднее	24.00	57.14	38.92	18.22	30.721	29.698	1.023	0.56	0.52	0.694	0.671
Итого	720.00				921.627	890.950	30.677			20.806	20.133

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11/2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46