

Отчет о потреблении тепловой энергии и теплоносителя с 21.03.2026 по 20.04.2026

Прибор Прибор: КАРАТ-307 (10123016)
Потребитель УК "Альтаир"
Адрес узла г. Туапсе, ул. Богдана Хмельницкого, д. 5

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1	
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, МПа	P2, МПа	Qпод, Гкал	Qобр, Гкал
21.03.2026	24.00	68.79	40.85	27.94	24.931	23.695	1.237	0.62	0.52	0.696	0.661
22.03.2026	24.00	67.33	40.13	27.20	24.398	23.255	1.143	0.63	0.52	0.663	0.632
23.03.2026	24.00	67.86	40.21	27.65	24.475	23.243	1.232	0.63	0.52	0.677	0.643
24.03.2026	24.00	66.62	40.87	25.76	25.422	24.248	1.173	0.59	0.52	0.703	0.671
25.03.2026	24.00	69.19	43.80	25.39	32.125	30.771	1.354	0.66	0.52	0.816	0.782
26.03.2026	24.00	66.32	42.47	23.85	31.930	30.484	1.446	0.66	0.52	0.761	0.727
27.03.2026	24.00	68.17	44.09	24.08	33.714	32.217	1.497	0.65	0.52	0.809	0.773
28.03.2026	24.00	67.89	43.82	24.07	32.238	30.865	1.372	0.65	0.52	0.776	0.743
29.03.2026	24.00	68.78	44.18	24.61	31.668	30.414	1.254	0.66	0.52	0.780	0.749
30.03.2026	24.00	67.92	44.38	23.54	33.236	31.815	1.421	0.68	0.52	0.779	0.746
31.03.2026	24.00	67.74	43.90	23.84	32.587	31.148	1.440	0.71	0.52	0.777	0.743
01.04.2026	24.00	65.53	42.66	22.87	31.979	30.523	1.456	0.68	0.52	0.726	0.693
02.04.2026	24.00	67.62	44.78	22.84	28.354	27.028	1.326	0.65	0.52	0.647	0.617
03.04.2026	24.00	67.23	49.59	17.64	28.493	27.139	1.354	0.65	0.52	0.503	0.479
04.04.2026	24.00	66.76	48.81	17.95	28.506	27.043	1.463	0.67	0.52	0.512	0.486
05.04.2026	24.00	68.96	49.86	19.10	28.226	26.774	1.451	0.68	0.52	0.540	0.512
06.04.2026	24.00	67.80	49.22	18.58	28.511	27.119	1.392	0.69	0.52	0.530	0.504
07.04.2026	24.00	66.51	48.45	18.06	28.291	26.818	1.473	0.69	0.52	0.511	0.485
08.04.2026	24.00	67.80	44.16	23.64	27.305	25.992	1.313	0.68	0.52	0.646	0.615
09.04.2026	24.00	69.23	40.94	28.28	27.318	25.945	1.374	0.68	0.52	0.773	0.734
10.04.2026	24.00	67.94	40.92	27.01	27.710	26.309	1.400	0.64	0.52	0.748	0.710
11.04.2026	24.00	67.80	41.14	26.66	27.954	26.503	1.451	0.62	0.52	0.746	0.707
12.04.2026	24.00	66.66	41.06	25.60	28.179	26.705	1.475	0.67	0.52	0.722	0.684
13.04.2026	24.00	60.77	39.17	21.61	27.500	26.109	1.392	0.65	0.52	0.625	0.593
14.04.2026	24.00	68.10	41.95	26.16	30.396	28.909	1.487	0.64	0.52	0.795	0.756
15.04.2026	24.00	70.26	43.60	26.65	30.432	29.222	1.210	0.62	0.52	0.810	0.778
16.04.2026	24.00	40.92	30.95	9.97	16.244	15.422	0.822	0.39	0.51	0.307	0.294
17.04.2026	24.00	46.92	37.00	9.92	15.116	14.617	0.499	0.43	0.52	0.397	0.385
18.04.2026	24.00	19.98	17.85	2.13	0.621	0.000	0.621	0.31	0.52	0.001	0.000
19.04.2026	24.00	16.19	14.28	1.91	1.408	0.000	1.408	0.31	0.51	0.003	0.000
Среднее	24.00	62.65	41.17	21.48	26.309	25.011	1.298	0.62	0.52	0.626	0.597
Итого	720.00				789.267	750.333	38.934			18.778	17.903

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11/2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46