

Отчет о потреблении тепловой энергии и теплоносителя с 21.11.2025 по 20.12.2025

Прибор Прибор: КАРАТ-307 (09351017)
Потребитель Жилой дом
Адрес узла г. Туапсе, ул. Звездная, д. 26

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1	
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Mтс, т	P1, МПа	P2, МПа	Qпод, Гкал	Qобр, Гкал
21.11.2025	24.00	39.25	32.66	6.59	72.921	67.720	5.201	0.60	0.55	0.481	0.445
22.11.2025	24.00	33.42	29.55	3.87	72.629	72.825	(0.196)	0.60	0.55	0.281	0.281
23.11.2025	24.00	30.27	27.50	2.77	72.704	72.962	(0.258)	0.60	0.55	0.202	0.203
24.11.2025	24.00	38.29	32.31	5.98	71.502	71.673	(0.171)	0.60	0.55	0.426	0.427
25.11.2025	24.00	39.92	33.07	6.86	68.941	69.103	(0.162)	0.60	0.55	0.471	0.472
26.11.2025	24.00	35.49	30.54	4.95	70.010	70.233	(0.223)	0.60	0.55	0.344	0.345
27.11.2025	24.00	39.92	33.01	6.91	72.347	72.532	(0.185)	0.60	0.55	0.500	0.501
28.11.2025	24.00	41.04	33.59	7.45	70.223	70.378	(0.154)	0.60	0.55	0.523	0.524
29.11.2025	24.00	41.21	33.52	7.68	67.889	68.028	(0.139)	0.60	0.55	0.520	0.521
30.11.2025	24.00	40.80	33.37	7.43	68.431	68.601	(0.170)	0.60	0.55	0.508	0.509
01.12.2025	24.00	40.99	33.02	7.97	66.499	66.633	(0.134)	0.60	0.55	0.528	0.529
02.12.2025	24.00	53.59	38.96	14.63	64.608	62.749	1.858	0.60	0.55	0.945	0.919
03.12.2025	24.00	54.15	39.44	14.71	64.516	64.522	(0.006)	0.60	0.55	0.949	0.949
04.12.2025	24.00	58.62	41.55	17.07	64.513	64.507	0.006	0.60	0.55	1.101	1.101
05.12.2025	24.00	59.19	41.91	17.28	64.447	64.450	(0.003)	0.60	0.55	1.113	1.113
06.12.2025	24.00	59.78	42.21	17.56	64.609	64.629	(0.019)	0.60	0.55	1.134	1.134
07.12.2025	24.00	59.06	41.87	17.19	64.691	64.723	(0.032)	0.60	0.55	1.111	1.112
08.12.2025	24.00	58.38	41.93	16.45	64.843	64.888	(0.045)	0.60	0.55	1.066	1.067
09.12.2025	24.00	53.61	39.84	13.76	64.782	64.866	(0.084)	0.60	0.55	0.897	0.898
10.12.2025	24.00	48.91	37.19	11.72	66.135	66.289	(0.155)	0.60	0.55	0.775	0.776
11.12.2025	24.00	55.19	40.18	15.02	66.827	66.889	(0.062)	0.60	0.55	1.003	1.004
12.12.2025	24.00	61.84	43.12	18.72	66.658	66.702	(0.043)	0.60	0.55	1.247	1.248
13.12.2025	24.00	63.77	43.75	20.02	65.181	65.181	0.000	0.60	0.55	1.304	1.304
14.12.2025	24.00	62.96	42.49	20.47	63.763	63.796	(0.033)	0.60	0.55	1.305	1.306
15.12.2025	24.00	63.77	42.81	20.96	63.261	63.350	(0.089)	0.60	0.55	1.325	1.327
16.12.2025	24.00	63.69	42.68	21.01	62.336	62.396	(0.060)	0.60	0.55	1.309	1.311
17.12.2025	24.00	64.20	42.99	21.21	62.052	62.153	(0.101)	0.60	0.55	1.316	1.318
18.12.2025	24.00	63.63	43.02	20.61	61.996	62.116	(0.121)	0.60	0.55	1.277	1.280
19.12.2025	24.00	63.74	43.32	20.42	61.930	62.031	(0.102)	0.60	0.55	1.264	1.266
20.12.2025	24.00	46.61	33.20	13.41	32.183	32.193	(0.010)	0.60	0.55	0.691	0.691
Среднее	24.00	51.18	37.82	13.36	65.447	65.304	0.144	0.60	0.55	0.864	0.863
Итого	720.00				1,963.425	1,959.119	4.306			25.917	25.882

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11/2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46