

Отчет о потреблении тепловой энергии и теплоносителя с 22.12.21 по 21.01.22

Прибор Прибор: КАРАТ-307 (09401017)
Потребитель Жилой дом
Адрес узла г. Туапсе, ул. Фрунзе, д. 53

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, МПа	P2, МПа	W, Гкал
22.12.2021	24.00	71.45	57.56	13.89	120.947	121.030	-0.084	0.60	0.55	1.672
23.12.2021	24.00	74.71	61.15	13.56	136.722	136.696	0.026	0.60	0.55	1.856
24.12.2021	24.00	73.00	59.99	13.02	136.717	136.678	0.039	0.60	0.55	1.782
25.12.2021	24.00	64.21	53.69	10.52	136.679	136.569	0.110	0.60	0.55	1.439
26.12.2021	24.00	58.10	49.38	8.72	137.310	137.097	0.214	0.60	0.55	1.198
27.12.2021	24.00	59.31	50.05	9.26	130.685	130.540	0.144	0.60	0.55	1.211
28.12.2021	24.00	57.47	48.57	8.91	126.095	125.956	0.139	0.60	0.55	1.124
29.12.2021	24.00	55.23	46.96	8.28	126.017	125.778	0.239	0.60	0.55	1.043
30.12.2021	24.00	54.44	46.25	8.19	125.919	125.673	0.246	0.60	0.55	1.032
31.12.2021	24.00	55.67	47.06	8.61	125.706	125.488	0.218	0.60	0.55	1.082
01.01.2022	24.00	55.18	46.71	8.47	125.795	125.557	0.238	0.60	0.55	1.066
02.01.2022	24.00	54.85	46.46	8.39	125.639	125.355	0.284	0.60	0.55	1.055
03.01.2022	24.00	56.53	47.33	9.20	125.335	125.138	0.197	0.60	0.55	1.153
04.01.2022	24.00	56.50	47.35	9.14	125.456	125.208	0.249	0.60	0.55	1.147
05.01.2022	24.00	56.19	47.27	8.92	125.413	125.203	0.210	0.60	0.55	1.119
06.01.2022	24.00	55.95	47.30	8.66	125.252	125.007	0.245	0.60	0.55	1.084
07.01.2022	24.00	55.29	46.95	8.35	125.205	124.931	0.274	0.60	0.55	1.045
08.01.2022	24.00	52.34	44.77	7.57	125.265	124.899	0.367	0.60	0.55	0.949
09.01.2022	24.00	53.40	45.39	8.00	125.036	124.732	0.304	0.60	0.55	1.001
10.01.2022	24.00	53.65	45.81	7.84	125.009	124.691	0.318	0.60	0.55	0.980
11.01.2022	24.00	55.20	46.33	8.87	114.552	114.376	0.175	0.60	0.55	1.003
12.01.2022	24.00	56.80	46.93	9.87	106.580	106.589	-0.009	0.60	0.55	1.052
13.01.2022	24.00	64.80	51.88	12.92	106.438	106.631	-0.193	0.60	0.55	1.375
14.01.2022	24.00	67.89	53.89	14.00	106.396	106.637	-0.242	0.60	0.55	1.490
15.01.2022	24.00	61.19	49.45	11.74	106.803	106.966	-0.163	0.60	0.55	1.254
16.01.2022	24.00	65.51	51.99	13.52	105.105	105.340	-0.235	0.60	0.55	1.421
17.01.2022	24.00	63.02	50.18	12.84	95.699	96.153	-0.453	0.60	0.55	1.314
18.01.2022	24.00	65.29	51.76	13.54	105.297	105.888	-0.592	0.60	0.55	1.426
19.01.2022	24.00	68.21	53.75	14.46	105.261	105.881	-0.620	0.60	0.55	1.523
20.01.2022	24.00	67.56	53.25	14.31	104.805	105.423	-0.618	0.60	0.55	1.501
21.01.2022	24.00	66.43	52.47	13.96	104.689	105.252	-0.563	0.60	0.55	1.462
Среднее	24.00	60.50	49.93	10.57	119.930	119.915	0.015	0.60	0.55	1.254
Итого	744.00				3,717.826	3,717.362	0.463			38.859

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 3
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46