

Отчет о потреблении тепловой энергии за период с 23.02.2022 по 22.03.2022

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 2

Тип прибора: БКТ-7
Номер прибора: 202114

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
23.02.2022	24,00	54,53	41,56	12,97	22,462	20,370	2,092	2,000	1,900	2,092	0,357
24.02.2022	24,00	52,88	40,93	11,95	23,329	20,510	2,819	2,000	1,900	2,819	0,366
25.02.2022	24,00	54,72	42,30	12,42	23,776	21,260	2,516	2,000	1,900	2,516	0,377
26.02.2022	24,00	54,09	41,64	12,45	23,228	20,620	2,608	2,000	1,900	2,608	0,372
27.02.2022	24,00	53,60	40,77	12,83	21,845	19,700	2,145	2,000	1,900	2,145	0,346
28.02.2022	24,00	55,15	42,96	12,19	25,713	23,700	2,013	2,000	1,900	2,013	0,380
01.03.2022	24,00	53,64	42,20	11,44	28,095	24,870	3,225	2,000	1,900	3,225	0,425
02.03.2022	24,00	53,88	42,37	11,51	27,870	24,650	3,220	2,000	1,900	3,220	0,425
03.03.2022	24,00	53,10	41,98	11,12	25,531	23,670	1,861	2,000	1,900	1,861	0,343
04.03.2022	24,00	53,58	41,69	11,89	24,630	22,520	2,110	2,000	1,900	2,110	0,360
05.03.2022	24,00	56,50	44,73	11,77	28,457	26,040	2,417	2,000	1,900	2,417	0,419
06.03.2022	24,00	52,85	40,21	12,64	23,187	20,800	2,387	2,000	1,900	2,387	0,365
07.03.2022	24,00	51,59	39,53	12,06	24,980	21,150	3,830	2,000	1,900	3,830	0,414
08.03.2022	24,00	53,44	40,10	13,34	21,773	19,810	1,963	2,000	1,900	1,963	0,350
09.03.2022	24,00	55,79	42,69	13,10	26,102	23,370	2,732	2,000	1,900	2,732	0,431
10.03.2022	24,00	53,55	43,01	10,54	30,962	29,410	1,552	2,000	1,900	1,552	0,378
11.03.2022	24,00	53,09	42,35	10,74	30,069	27,240	2,829	2,000	1,900	2,829	0,414
12.03.2022	24,00	54,56	42,31	12,25	27,449	25,130	2,319	2,000	1,900	2,319	0,411
13.03.2022	24,00	57,20	44,99	12,21	29,342	26,330	3,012	2,000	1,900	3,012	0,464
14.03.2022	24,00	52,56	41,91	10,65	28,015	25,770	2,245	2,000	1,900	2,245	0,370
15.03.2022	24,00	51,84	41,82	10,02	30,339	27,900	2,439	2,000	1,900	2,439	0,382
16.03.2022	24,00	53,82	44,04	9,78	38,387	36,280	2,107	2,000	1,900	2,107	0,447
17.03.2022	24,00	54,45	44,29	10,16	37,607	35,290	2,317	2,000	1,900	2,317	0,462
18.03.2022	24,00	54,39	44,39	10,00	38,547	36,250	2,297	2,000	1,900	2,297	0,464
19.03.2022	24,00	53,95	43,98	9,97	40,207	36,990	3,217	2,000	1,900	3,217	0,510
20.03.2022	24,00	53,69	43,44	10,25	36,737	34,200	2,537	2,000	1,900	2,537	0,461
21.03.2022	24,00	53,47	40,85	12,62	26,631	24,000	2,631	2,000	1,900	2,631	0,417
22.03.2022	24,00	53,79	41,02	12,77	26,096	23,320	2,776	2,000	1,900	2,776	0,419
Среднее	24,00	53,92	42,29	11,63	28,263	25,755	2,508	2,000	1,900	2,508	0,405
Итого	672,00				791,365	721,150	70,215			70,215	11,330

Механические показания: V1=_____V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46

Подготовлен программным комплексом «Взлет СП». www.vzljot.ru