

Отчет о потреблении тепловой энергии за период с 23.03.2022 по 22.04.2022

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 2

Тип прибора: БКТ-7
Номер прибора: 202114

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
23.03.2022	24,00	53,44	40,64	12,80	23,906	21,790	2,116	2,000	1,900	2,116	0,371
24.03.2022	24,00	53,36	42,78	10,58	26,595	24,150	2,445	2,000	1,900	2,445	0,362
25.03.2022	24,00	52,64	41,86	10,78	25,037	22,440	2,597	2,000	1,900	2,597	0,353
26.03.2022	24,00	54,58	43,27	11,31	26,405	24,300	2,105	2,000	1,900	2,105	0,369
27.03.2022	24,00	53,69	42,66	11,03	27,715	25,600	2,115	2,000	1,900	2,115	0,375
28.03.2022	24,00	52,07	39,81	12,26	24,098	21,220	2,878	2,000	1,900	2,878	0,381
29.03.2022	24,00	52,73	40,77	11,96	24,321	22,050	2,271	2,000	1,900	2,271	0,361
30.03.2022	24,00	52,77	40,78	11,99	24,592	22,170	2,422	2,000	1,900	2,422	0,369
31.03.2022	24,00	53,32	40,93	12,39	23,513	21,070	2,443	2,000	1,900	2,443	0,367
01.04.2022	24,00	52,25	40,37	11,88	21,791	19,750	2,041	2,000	1,900	2,041	0,321
02.04.2022	24,00	52,67	41,66	11,01	25,153	22,960	2,193	2,000	1,900	2,193	0,346
03.04.2022	24,00	52,51	41,98	10,53	24,876	22,420	2,456	2,000	1,900	2,456	0,340
04.04.2022	24,00	50,58	40,14	10,44	22,243	19,740	2,503	2,000	1,900	2,503	0,308
05.04.2022	24,00	51,91	42,93	8,98	30,929	28,250	2,679	2,000	1,900	2,679	0,366
06.04.2022	24,00	53,35	44,65	8,70	35,508	33,320	2,188	2,000	1,900	2,188	0,385
07.04.2022	24,00	55,12	46,06	9,06	37,114	34,490	2,624	2,000	1,900	2,624	0,431
08.04.2022	24,00	54,92	46,22	8,70	35,999	34,090	1,909	2,000	1,900	1,909	0,382
09.04.2022	24,00	54,58	46,07	8,51	41,881	39,470	2,411	2,000	1,900	2,411	0,443
10.04.2022	24,00	56,64	46,78	9,86	37,645	34,970	2,675	2,000	1,900	2,675	0,470
11.04.2022	24,00	53,16	43,70	9,46	32,051	29,620	2,431	2,000	1,900	2,431	0,385
12.04.2022	24,00	53,65	43,05	10,60	32,126	29,690	2,436	2,000	1,900	2,436	0,421
13.04.2022	24,00	54,76	43,49	11,27	31,938	29,610	2,328	2,000	1,900	2,328	0,438
14.04.2022	24,00	53,26	42,20	11,06	33,420	30,720	2,700	2,000	1,900	2,700	0,457
15.04.2022	24,00	54,56	43,79	10,77	31,554	29,630	1,924	2,000	1,900	1,924	0,405
16.04.2022	24,00	56,11	45,35	10,76	32,901	30,470	2,431	2,000	1,900	2,431	0,440
17.04.2022	24,00	53,61	43,87	9,74	33,226	31,010	2,216	2,000	1,900	2,216	0,399
18.04.2022	24,00	54,24	44,17	10,07	32,033	29,870	2,163	2,000	1,900	2,163	0,396
19.04.2022	24,00	55,40	44,08	11,32	31,045	29,450	1,595	2,000	1,900	1,595	0,406
20.04.2022	24,00	53,48	41,22	12,26	24,551	22,160	2,391	2,000	1,900	2,391	0,376
21.04.2022	24,00	50,86	35,06	15,80	15,841	13,510	2,331	2,000	1,900	2,331	0,309
22.04.2022	24,00	51,06	35,62	15,44	16,565	14,460	2,105	2,000	1,900	2,105	0,310
Среднее	24,00	53,46	42,45	11,01	28,599	26,273	2,327	2,000	1,900	2,327	0,382
Итого	744,00				886,572	814,450	72,122			72,122	11,839

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46

Подготовлен программным комплексом «Взлет СП». www.vzljot.ru