

Отчет о потреблении тепловой энергии за период с 19.02.2023 по 21.03.2023

Потребитель: Жилой дом

Тип прибора: БКТ-7

Адрес: г. Туапсе, ул. Звёздная, д. 39 блок 1

Номер прибора: 110747

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
19.02.2023	24,00	52,00	43,75	8,25	15,140	10,320	4,820	5,000	5,000	4,820	0,280
20.02.2023	24,00	53,25	45,29	7,96	14,940	11,300	3,640	5,000	5,000	3,640	0,246
21.02.2023	24,00	51,35	43,94	7,41	15,680	11,620	4,060	5,000	5,000	4,060	0,251
22.02.2023	24,00	51,71	43,41	8,30	13,430	9,460	3,970	5,000	5,000	3,970	0,238
23.02.2023	24,00	51,61	43,43	8,18	14,250	10,220	4,030	5,000	5,000	4,030	0,248
24.02.2023	24,00	55,69	47,61	8,08	18,050	14,160	3,890	5,000	5,000	3,890	0,288
25.02.2023	24,00	53,73	45,49	8,24	15,520	11,120	4,400	5,000	5,000	4,400	0,281
26.02.2023	24,00	52,22	44,22	8,00	15,250	11,430	3,820	5,000	5,000	3,820	0,250
27.02.2023	24,00	51,91	43,94	7,97	14,080	10,910	3,170	5,000	5,000	3,170	0,216
28.02.2023	24,00	51,04	43,26	7,78	13,870	10,640	3,230	5,000	5,000	3,230	0,212
01.03.2023	24,00	50,42	43,07	7,35	14,400	10,890	3,510	5,000	5,000	3,510	0,220
02.03.2023	24,00	51,85	43,78	8,07	15,310	10,890	4,420	5,000	5,000	4,420	0,271
03.03.2023	24,00	50,81	43,05	7,76	13,990	10,490	3,500	5,000	5,000	3,500	0,219
04.03.2023	24,00	52,08	43,87	8,21	14,010	10,460	3,550	5,000	5,000	3,550	0,232
05.03.2023	24,00	50,69	43,26	7,43	15,490	10,970	4,520	5,000	5,000	4,520	0,260
06.03.2023	24,00	51,43	43,67	7,76	14,620	11,130	3,490	5,000	5,000	3,490	0,230
07.03.2023	24,00	49,08	41,93	7,15	15,040	10,960	4,080	5,000	5,000	4,080	0,233
08.03.2023	24,00	53,17	44,93	8,24	15,050	10,890	4,160	5,000	5,000	4,160	0,267
09.03.2023	24,00	51,51	43,86	7,65	14,810	11,140	3,670	5,000	5,000	3,670	0,237
10.03.2023	24,00	52,37	44,54	7,83	14,600	11,070	3,530	5,000	5,000	3,530	0,236
11.03.2023	24,00	51,93	43,86	8,07	14,430	10,630	3,800	5,000	5,000	3,800	0,242
12.03.2023	24,00	52,91	44,53	8,38	14,260	10,300	3,960	5,000	5,000	3,960	0,251
13.03.2023	24,00	48,03	41,08	6,95	14,970	10,610	4,360	5,000	5,000	4,360	0,234
14.03.2023	24,00	51,04	43,60	7,44	13,300	9,580	3,720	5,000	5,000	3,720	0,219
15.03.2023	24,00	49,76	42,05	7,71	13,840	10,050	3,790	5,000	5,000	3,790	0,220
16.03.2023	24,00	51,50	44,26	7,24	14,690	10,780	3,910	5,000	5,000	3,910	0,235
17.03.2023	24,00	52,20	44,33	7,87	14,610	10,670	3,940	5,000	5,000	3,940	0,246
18.03.2023	24,00	53,89	45,52	8,37	14,760	11,260	3,500	5,000	5,000	3,500	0,247
19.03.2023	24,00	51,93	43,68	8,25	14,340	10,440	3,900	5,000	5,000	3,900	0,245
20.03.2023	24,00	53,58	45,11	8,47	13,990	10,440	3,550	5,000	5,000	3,550	0,242
21.03.2023	24,00	52,07	44,12	7,95	14,440	10,150	4,290	5,000	5,000	4,290	0,259
Среднее	24,00	51,83	43,95	7,88	14,683	10,806	3,877	5,000	5,000	3,877	0,244
Итого	744,00				455,160	334,980	120,180			120,180	7,555

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru