

Отчет о потреблении тепловой энергии за период с 22.03.2023 по 20.04.2023

Потребитель: Жилой дом

Тип прибора: БКТ-7

Адрес: г. Туапсе, ул. Звёздная, д. 39 блок 1

Номер прибора: 110747

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
22.03.2023	24,00	52,22	44,35	7,87	14,620	10,800	3,820	5,000	5,000	3,820	0,243
23.03.2023	24,00	52,56	44,44	8,12	14,210	10,590	3,620	5,000	5,000	3,620	0,237
24.03.2023	24,00	52,87	44,32	8,55	13,120	9,990	3,130	5,000	5,000	3,130	0,214
25.03.2023	24,00	54,23	45,26	8,97	13,680	9,870	3,810	5,000	5,000	3,810	0,253
26.03.2023	23,00	52,89	43,48	9,41	12,860	8,470	4,390	5,000	5,000	4,390	0,260
27.03.2023	24,00	51,07	42,29	8,78	13,070	8,970	4,100	5,000	5,000	4,100	0,242
28.03.2023	24,00	51,06	42,57	8,49	13,120	8,700	4,420	5,000	5,000	4,420	0,249
29.03.2023	24,00	52,90	43,38	9,52	12,650	8,630	4,020	5,000	5,000	4,020	0,246
30.03.2023	24,00	53,42	43,56	9,86	12,540	8,450	4,090	5,000	5,000	4,090	0,255
31.03.2023	24,00	51,29	42,06	9,23	11,870	8,430	3,440	5,000	5,000	3,440	0,212
01.04.2023	24,00	52,98	43,13	9,85	12,120	7,840	4,280	5,000	5,000	4,280	0,250
02.04.2023	24,00	49,43	41,51	7,92	12,950	8,820	4,130	5,000	5,000	4,130	0,223
03.04.2023	24,00	51,62	42,50	9,12	11,080	7,760	3,320	5,000	5,000	3,320	0,200
04.04.2023	24,00	55,36	44,69	10,67	10,800	8,070	2,730	5,000	5,000	2,730	0,205
05.04.2023	24,00	52,94	43,33	9,61	11,120	7,480	3,640	5,000	5,000	3,640	0,219
06.04.2023	24,00	50,08	40,87	9,21	11,060	7,540	3,520	5,000	5,000	3,520	0,201
07.04.2023	24,00	52,47	42,46	10,01	11,170	7,900	3,270	5,000	5,000	3,270	0,209
08.04.2023	24,00	53,53	43,45	10,08	11,720	7,760	3,960	5,000	5,000	3,960	0,241
09.04.2023	24,00	51,13	41,83	9,30	11,570	7,830	3,740	5,000	5,000	3,740	0,218
10.04.2023	24,00	53,21	43,47	9,74	11,950	8,550	3,400	5,000	5,000	3,400	0,222
11.04.2023	24,00	52,96	43,85	9,11	12,230	8,970	3,260	5,000	5,000	3,260	0,215
12.04.2023	24,00	52,12	42,88	9,24	12,090	8,000	4,090	5,000	5,000	4,090	0,235
13.04.2023	24,00	51,71	43,06	8,65	12,880	8,060	4,820	5,000	5,000	4,820	0,262
14.04.2023	24,00	51,15	41,80	9,35	11,580	8,140	3,440	5,000	5,000	3,440	0,210
15.04.2023	24,00	52,69	43,85	8,84	13,200	9,020	4,180	5,000	5,000	4,180	0,253
16.04.2023	24,00	51,39	42,60	8,79	12,460	8,400	4,060	5,000	5,000	4,060	0,234
17.04.2023	24,00	45,81	39,38	6,43	12,930	8,460	4,470	5,000	5,000	4,470	0,209
18.04.2023	24,00	47,53	39,85	7,68	12,070	8,530	3,540	5,000	5,000	3,540	0,192
19.04.2023	24,00	49,52	40,93	8,59	11,950	7,770	4,180	5,000	5,000	4,180	0,224
20.04.2023	24,00	47,34	39,25	8,09	11,530	7,700	3,830	5,000	5,000	3,830	0,199
Среднее	23,97	51,65	42,68	8,97	12,340	8,517	3,823	5,000	5,000	3,823	0,228
Итого	719,00				370,200	255,500	114,700			114,700	6,832

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru