

Отчет о потреблении тепловой энергии за период с 21.06.2023 по 21.07.2023

Потребитель: Жилой дом

Адрес: г. Туапсе, ул. Звёздная, д. 39 блок 1

Тип прибора: БКТ-7

Номер прибора: 110747

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
21.06.2023	24,00	51,25	42,98	8,27	13,180	9,140	4,040	5,000	5,000	4,040	0,237
22.06.2023	24,00	50,93	41,71	9,22	10,840	7,400	3,440	5,000	5,000	3,440	0,205
23.06.2023	24,00	49,81	41,97	7,84	12,910	8,720	4,190	5,000	5,000	4,190	0,229
24.06.2023	24,00	50,55	42,88	7,67	13,110	9,300	3,810	5,000	5,000	3,810	0,221
25.06.2023	24,00	50,04	42,53	7,51	13,380	9,230	4,150	5,000	5,000	4,150	0,228
26.06.2023	24,00	50,42	42,39	8,03	12,850	8,440	4,410	5,000	5,000	4,410	0,237
27.06.2023	24,00	50,58	42,80	7,78	12,420	8,810	3,610	5,000	5,000	3,610	0,209
28.06.2023	24,00	50,24	42,55	7,69	12,700	8,730	3,970	5,000	5,000	3,970	0,221
29.06.2023	24,00	51,36	43,11	8,25	12,690	8,530	4,160	5,000	5,000	4,160	0,236
30.06.2023	24,00	50,96	41,79	9,17	10,000	5,860	4,140	5,000	5,000	4,140	0,217
01.07.2023	24,00	49,41	41,62	7,79	12,330	8,840	3,490	5,000	5,000	3,490	0,198
02.07.2023	24,00	49,93	42,05	7,88	13,090	8,420	4,670	5,000	5,000	4,670	0,245
03.07.2023	24,00	50,09	42,41	7,68	13,660	9,270	4,390	5,000	5,000	4,390	0,241
04.07.2023	24,00	51,08	43,06	8,02	12,830	8,850	3,980	5,000	5,000	3,980	0,226
05.07.2023	24,00	49,85	42,81	7,04	13,230	9,240	3,990	5,000	5,000	3,990	0,215
06.07.2023	24,00	51,04	43,77	7,27	12,890	9,490	3,400	5,000	5,000	3,400	0,202
07.07.2023	24,00	52,48	44,54	7,94	12,950	9,220	3,730	5,000	5,000	3,730	0,228
08.07.2023	24,00	51,48	43,54	7,94	12,390	8,830	3,560	5,000	5,000	3,560	0,211
09.07.2023	24,00	51,32	43,52	7,80	13,280	9,100	4,180	5,000	5,000	4,180	0,236
10.07.2023	24,00	48,99	41,54	7,45	11,990	8,230	3,760	5,000	5,000	3,760	0,204
11.07.2023	24,00	49,29	41,32	7,97	12,500	8,690	3,810	5,000	5,000	3,810	0,215
12.07.2023	24,00	49,39	40,78	8,61	12,330	6,700	5,630	5,000	5,000	5,630	0,272
13.07.2023	24,00	47,09	39,93	7,16	12,310	8,100	4,210	5,000	5,000	4,210	0,210
14.07.2023	24,00	48,39	41,08	7,31	13,660	9,010	4,650	5,000	5,000	4,650	0,238
15.07.2023	24,00	49,31	41,79	7,52	13,450	9,460	3,990	5,000	5,000	3,990	0,221
16.07.2023	24,00	49,68	40,96	8,72	11,080	7,110	3,970	5,000	5,000	3,970	0,215
17.07.2023	24,00	47,92	40,95	6,97	13,360	8,480	4,880	5,000	5,000	4,880	0,240
18.07.2023	24,00	49,77	42,17	7,60	13,210	9,000	4,210	5,000	5,000	4,210	0,227
19.07.2023	24,00	49,83	42,64	7,19	14,840	9,610	5,230	5,000	5,000	5,230	0,269
20.07.2023	24,00	50,49	43,08	7,41	13,850	9,610	4,240	5,000	5,000	4,240	0,237
21.07.2023	24,00	49,54	42,72	6,82	13,500	9,340	4,160	5,000	5,000	4,160	0,222
Среднее	24,00	50,08	42,29	7,79	12,800	8,670	4,131	5,000	5,000	4,131	0,226
Итого	744,00				396,810	268,760	128,050			128,050	7,012

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru