

Отчет о потреблении тепловой энергии за период с 21.04.2023 по 21.05.2023

Потребитель: Жилой дом
Адрес: г. Туапсе, ул. Кириченко, д. 4А

Тип прибора: ВКТ-7
Номер прибора: 74026

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
21.04.2023	24,00	57,39	49,64	7,75	13,770	10,320	3,450	4,000	3,500	3,450	0,241
22.04.2023	24,00	55,28	47,80	7,48	16,270	12,740	3,530	4,000	3,500	3,530	0,255
23.04.2023	24,00	56,47	48,97	7,50	17,050	12,450	4,600	4,000	3,500	4,600	0,304
24.04.2023	24,00	57,79	49,96	7,83	13,740	10,190	3,550	4,000	3,500	3,550	0,248
25.04.2023	24,00	55,36	48,06	7,30	16,040	12,210	3,830	4,000	3,500	3,830	0,259
26.04.2023	24,00	56,03	48,80	7,23	18,310	15,370	2,940	4,000	3,500	2,940	0,239
27.04.2023	24,00	58,16	50,30	7,86	13,030	10,230	2,800	4,000	3,500	2,800	0,212
28.04.2023	24,00	57,13	49,05	8,08	15,910	12,730	3,180	4,000	3,500	3,180	0,248
29.04.2023	24,00	57,94	49,37	8,57	16,000	12,860	3,140	4,000	3,500	3,140	0,258
30.04.2023	24,00	59,03	50,98	8,05	16,240	12,670	3,570	4,000	3,500	3,570	0,274
01.05.2023	24,00	57,87	49,56	8,31	16,120	12,590	3,530	4,000	3,500	3,530	0,272
02.05.2023	24,00	56,82	48,35	8,47	15,900	12,580	3,320	4,000	3,500	3,320	0,259
03.05.2023	24,00	55,08	47,59	7,49	15,120	11,520	3,600	4,000	3,500	3,600	0,243
04.05.2023	24,00	58,49	51,46	7,03	20,430	17,740	2,690	4,000	3,500	2,690	0,247
05.05.2023	24,00	56,56	49,47	7,09	18,300	15,560	2,740	4,000	3,500	2,740	0,236
06.05.2023	24,00	58,32	50,69	7,63	18,230	15,020	3,210	4,000	3,500	3,210	0,270
07.05.2023	24,00	58,84	51,25	7,59	18,090	15,440	2,650	4,000	3,500	2,650	0,245
08.05.2023	24,00	57,26	50,22	7,04	18,030	15,190	2,840	4,000	3,500	2,840	0,240
09.05.2023	24,00	57,10	49,98	7,12	16,080	11,680	4,400	4,000	3,500	4,400	0,289
10.05.2023	24,00	59,01	51,18	7,83	17,650	15,540	2,110	4,000	3,500	2,110	0,221
11.05.2023	24,00	58,55	51,24	7,31	18,520	16,180	2,340	4,000	3,500	2,340	0,230
12.05.2023	24,00	55,68	48,95	6,73	18,930	15,940	2,990	4,000	3,500	2,990	0,242
13.05.2023	24,00	57,33	50,36	6,97	18,470	16,180	2,290	4,000	3,500	2,290	0,219
14.05.2023	24,00	55,36	48,77	6,59	19,350	15,750	3,600	4,000	3,500	3,600	0,265
15.05.2023	24,00	58,45	51,08	7,37	19,180	15,860	3,320	4,000	3,500	3,320	0,275
16.05.2023	24,00	57,80	49,92	7,88	15,580	12,960	2,620	4,000	3,500	2,620	0,221
17.05.2023	24,00	56,57	47,35	9,22	11,850	9,830	2,020	4,000	3,500	2,020	0,180
18.05.2023	24,00	55,44	41,39	14,05	4,900	4,720	0,180	4,000	3,500	0,180	0,077
19.05.2023	24,00	57,49	47,80	9,69	10,140	8,170	1,970	4,000	3,500	1,970	0,172
20.05.2023	24,00	56,97	49,53	7,44	15,810	13,190	2,620	4,000	3,500	2,620	0,218
21.05.2023	24,00	57,17	49,65	7,52	13,800	10,430	3,370	4,000	3,500	3,370	0,237
Среднее	24,00	57,19	49,31	7,87	16,027	13,027	3,000	4,000	3,500	3,000	0,239
Итого	744,00				496,840	403,840	93,000			93,000	7,396

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru