

Отчет о потреблении тепловой энергии и теплоносителя с 29.10.22 по 21.11.22

Прибор Прибор: КАРАТ-307 (14511417)
Потребитель Жилой дом
Адрес узла г. Туапсе, ул. Маршала Жукова, д. 20/6

Дата	ВР, ч	Теплосистема 1 - Отопление								Итого по ТС1
		t1, °C	t2, °C	dt, °C	M1, т	M2, т	Мтс, т	P1, МПа	P2, МПа	W, Гкал
29.10.2022	24.00	16.33	16.25	0.08	0.405	0.000	0.405	3.84	3.87	0.000
30.10.2022	24.00	16.24	16.13	0.11	0.404	0.000	0.404	3.83	3.86	0.000
31.10.2022	24.00	31.84	26.89	4.95	28.859	28.947	-0.088	4.42	4.38	0.299
01.11.2022	24.00	44.82	36.93	7.90	70.807	71.481	-0.674	5.16	5.06	0.558
02.11.2022	24.00	45.15	36.65	8.51	66.167	66.959	-0.792	5.16	5.08	0.562
03.11.2022	24.00	36.18	30.43	5.75	64.573	65.099	-0.527	5.62	5.56	0.366
04.11.2022	24.00	47.50	35.29	12.21	62.212	63.600	-1.388	5.33	5.29	0.746
05.11.2022	24.00	63.45	40.24	23.21	58.619	60.333	-1.714	5.64	5.62	1.360
06.11.2022	24.00	63.92	37.34	26.58	57.265	60.082	-2.817	5.60	5.59	1.521
07.11.2022	24.00	58.42	35.37	23.06	57.677	60.472	-2.795	5.65	5.63	1.329
08.11.2022	24.00	58.88	35.42	23.46	57.731	60.539	-2.809	5.69	5.67	1.353
09.11.2022	24.00	48.95	32.27	16.68	58.949	61.095	-2.147	5.63	5.61	0.978
10.11.2022	24.00	45.78	31.13	14.64	58.858	60.779	-1.920	5.46	5.44	0.860
11.11.2022	24.00	45.52	29.75	15.77	57.595	59.602	-2.006	5.71	5.69	0.895
12.11.2022	24.00	60.95	34.78	26.17	53.994	56.949	-2.955	6.35	6.35	1.411
13.11.2022	24.00	55.18	33.80	21.38	53.968	56.465	-2.497	5.68	5.67	1.147
14.11.2022	24.00	49.68	31.43	18.24	53.818	56.298	-2.480	7.04	7.03	0.980
15.11.2022	24.00	45.38	30.20	15.18	54.831	56.918	-2.087	7.36	7.35	0.831
16.11.2022	24.00	50.63	31.21	19.42	54.961	57.402	-2.441	6.82	6.81	1.069
17.11.2022	24.00	69.64	37.10	32.54	51.918	54.995	-3.076	5.68	5.68	1.687
18.11.2022	24.00	67.17	36.37	30.80	50.258	53.172	-2.914	5.57	5.57	1.549
19.11.2022	24.00	66.61	36.88	29.74	50.507	53.296	-2.789	5.69	5.68	1.501
20.11.2022	24.00	66.19	37.21	28.98	50.936	53.649	-2.714	5.70	5.69	1.476
21.11.2022	24.00	36.38	28.39	7.99	26.183	26.361	-0.178	3.77	3.94	0.386
Среднее	24.00	49.62	32.39	17.22	50.062	51.854	-1.792	5.52	5.51	0.953
Итого	576.00				1,201.495	1,244.492	-42.997			22.862

Отчет подготовил: инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 3
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46