

Отчет о потреблении тепловой энергии за период с 21.11.2023 по 21.12.2023

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 1

Тип прибора: БКТ-7
Номер прибора: 212180

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
21.11.2023	24,00	54,65	40,33	14,32	26,960	21,320	5,640	4,000	3,500	5,640	0,546
22.11.2023	24,00	53,69	39,39	14,30	26,390	21,690	4,700	4,000	3,500	4,700	0,507
23.11.2023	24,00	54,80	40,08	14,72	26,910	21,160	5,750	4,000	3,500	5,750	0,559
24.11.2023	24,00	52,99	38,68	14,31	26,580	21,120	5,460	4,000	3,500	5,460	0,528
25.11.2023	24,00	53,27	39,27	14,00	26,650	21,820	4,830	4,000	3,500	4,830	0,506
26.11.2023	24,00	52,54	39,01	13,53	26,970	21,110	5,860	4,000	3,500	5,860	0,528
27.11.2023	24,00	53,81	39,65	14,16	26,000	21,080	4,920	4,000	3,500	4,920	0,504
28.11.2023	24,00	55,62	40,11	15,51	26,190	21,430	4,760	4,000	3,500	4,760	0,539
29.11.2023	24,00	53,89	39,15	14,74	26,220	21,050	5,170	4,000	3,500	5,170	0,530
30.11.2023	24,00	53,13	38,93	14,20	26,010	21,250	4,760	4,000	3,500	4,760	0,501
01.12.2023	24,00	55,06	39,94	15,12	26,060	21,390	4,670	4,000	3,500	4,670	0,521
02.12.2023	24,00	54,20	39,92	14,28	26,170	21,430	4,740	4,000	3,500	4,740	0,507
03.12.2023	24,00	51,60	39,02	12,58	26,530	21,040	5,490	4,000	3,500	5,490	0,487
04.12.2023	24,00	51,17	38,84	12,33	26,220	20,910	5,310	4,000	3,500	5,310	0,473
05.12.2023	24,00	54,33	39,90	14,43	25,820	20,950	4,870	4,000	3,500	4,870	0,507
06.12.2023	24,00	54,79	40,35	14,44	25,910	20,200	5,710	4,000	3,500	5,710	0,536
07.12.2023	24,00	52,89	39,71	13,18	26,210	19,780	6,430	4,000	3,500	6,430	0,527
08.12.2023	24,00	50,68	38,43	12,25	25,380	20,330	5,050	4,000	3,500	5,050	0,450
09.12.2023	24,00	51,25	38,90	12,35	25,010	20,690	4,320	4,000	3,500	4,320	0,428
10.12.2023	24,00	51,46	38,59	12,87	25,910	20,060	5,850	4,000	3,500	5,850	0,494
11.12.2023	24,00	53,81	40,03	13,78	25,750	21,500	4,250	4,000	3,500	4,250	0,474
12.12.2023	24,00	48,96	37,88	11,08	25,430	20,100	5,330	4,000	3,500	5,330	0,424
13.12.2023	24,00	46,89	36,22	10,67	25,340	19,810	5,530	4,000	3,500	5,530	0,410
14.12.2023	24,00	50,29	37,65	12,64	24,970	20,080	4,890	4,000	3,500	4,890	0,445
15.12.2023	24,00	50,75	38,08	12,67	24,820	20,690	4,130	4,000	3,500	4,130	0,429
16.12.2023	24,00	50,52	37,97	12,55	25,590	20,130	5,460	4,000	3,500	5,460	0,467
17.12.2023	24,00	50,02	37,27	12,75	26,340	20,400	5,940	4,000	3,500	5,940	0,491
18.12.2023	24,00	51,95	37,88	14,07	25,850	20,120	5,730	4,000	3,500	5,730	0,517
19.12.2023	24,00	49,22	36,50	12,72	25,700	20,270	5,430	4,000	3,500	5,430	0,466
20.12.2023	24,00	49,53	36,38	13,15	25,420	19,100	6,320	4,000	3,500	6,320	0,496
21.12.2023	24,00	50,21	36,67	13,54	25,180	17,900	7,280	4,000	3,500	7,280	0,528
Среднее	24,00	52,19	38,73	13,46	25,951	20,642	5,309	4,000	3,500	5,309	0,494
Итого	744,00				804,490	639,910	164,580			164,580	15,325

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru