

Отчет о потреблении тепловой энергии за период с 22.12.2023 по 21.01.2024

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 1

Тип прибора: БКТ-7
Номер прибора: 212180

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
22.12.2023	24,00	53,40	38,52	14,88	24,770	19,730	5,040	4,000	3,500	5,040	0,504
23.12.2023	24,00	49,27	36,58	12,69	24,950	19,460	5,490	4,000	3,500	5,490	0,456
24.12.2023	24,00	48,69	35,98	12,71	25,640	19,200	6,440	4,000	3,500	6,440	0,488
25.12.2023	24,00	47,83	35,28	12,55	25,740	18,860	6,880	4,000	3,500	6,880	0,489
26.12.2023	24,00	49,95	36,02	13,93	15,690	12,280	3,410	4,000	3,500	3,410	0,302
27.12.2023	24,00	49,79	36,91	12,88	25,770	19,860	5,910	4,000	3,500	5,910	0,485
28.12.2023	24,00	52,01	38,25	13,76	27,390	20,550	6,840	4,000	3,500	6,840	0,562
29.12.2023	24,00	55,28	40,42	14,86	28,580	22,590	5,990	4,000	3,500	5,990	0,596
30.12.2023	24,00	55,28	40,65	14,63	29,260	21,580	7,680	4,000	3,500	7,680	0,651
31.12.2023	24,00	55,44	40,45	14,99	29,080	21,410	7,670	4,000	3,500	7,670	0,658
01.01.2024	24,00	57,55	41,85	15,70	27,580	23,100	4,480	4,000	3,500	4,480	0,559
02.01.2024	24,00	56,33	41,48	14,85	28,090	22,700	5,390	4,000	3,500	5,390	0,571
03.01.2024	24,00	54,59	40,14	14,45	28,260	21,820	6,440	4,000	3,500	6,440	0,588
04.01.2024	24,00	52,66	39,09	13,57	28,170	22,070	6,100	4,000	3,500	6,100	0,553
05.01.2024	24,00	52,41	38,91	13,50	28,340	21,780	6,560	4,000	3,500	6,560	0,561
06.01.2024	24,00	55,40	40,78	14,62	27,950	22,040	5,910	4,000	3,500	5,910	0,578
07.01.2024	24,00	53,39	39,69	13,70	27,620	22,090	5,530	4,000	3,500	5,530	0,533
08.01.2024	24,00	53,24	39,51	13,73	28,080	21,810	6,270	4,000	3,500	6,270	0,563
09.01.2024	24,00	52,67	39,27	13,40	27,940	22,240	5,700	4,000	3,500	5,700	0,530
10.01.2024	24,00	55,01	39,92	15,09	28,110	21,670	6,440	4,000	3,500	6,440	0,606
11.01.2024	24,00	54,92	39,95	14,97	28,460	21,650	6,810	4,000	3,500	6,810	0,616
12.01.2024	24,00	52,48	38,59	13,89	27,740	22,310	5,430	4,000	3,500	5,430	0,532
13.01.2024	24,00	55,39	39,58	15,81	28,250	22,250	6,000	4,000	3,500	6,000	0,610
14.01.2024	24,00	54,02	42,58	11,44	30,050	24,250	5,800	4,000	3,500	5,800	0,524
15.01.2024	24,00	50,28	40,49	9,79	19,500	11,700	7,800	4,000	3,500	7,800	0,420
16.01.2024	24,00	50,71	35,37	15,34	15,560	8,170	7,390	4,000	3,500	7,390	0,417
17.01.2024	24,00	52,06	36,06	16,00	20,310	14,460	5,850	4,000	3,500	5,850	0,465
18.01.2024	24,00	54,47	42,54	11,93	37,910	31,590	6,320	4,000	3,500	6,320	0,642
19.01.2024	24,00	52,14	40,19	11,95	31,400	25,660	5,740	4,000	3,500	5,740	0,539
20.01.2024	24,00	53,08	37,64	15,44	24,530	18,530	6,000	4,000	3,500	6,000	0,536
21.01.2024	24,00	52,00	36,66	15,34	25,250	17,710	7,540	4,000	3,500	7,540	0,579
Среднее	24,00	52,96	39,01	13,95	26,644	20,488	6,156	4,000	3,500	6,156	0,539
Итого	744,00				825,970	635,120	190,850			190,850	16,713

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru