

Отчет о потреблении тепловой энергии за период
с 22.01.2024 по 22.02.2024

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 1

Тип прибора: БКТ-7
Номер прибора: 212180

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
22.01.2024	24,00	51,60	36,95	14,65	20,350	15,640	4,710	4,000	3,500	4,710	0,417
23.01.2024	24,00	53,90	37,95	15,95	26,530	20,390	6,140	4,000	3,500	6,140	0,586
24.01.2024	24,00	55,33	39,20	16,13	26,080	20,900	5,180	4,000	3,500	5,180	0,559
25.01.2024	24,00	52,01	37,55	14,46	26,280	20,570	5,710	4,000	3,500	5,710	0,531
26.01.2024	24,00	50,45	36,45	14,00	26,020	19,730	6,290	4,000	3,500	6,290	0,521
27.01.2024	24,00	53,77	38,59	15,18	25,320	18,700	6,620	4,000	3,500	6,620	0,564
28.01.2024	24,00	52,78	38,27	14,51	23,420	17,280	6,140	4,000	3,500	6,140	0,504
29.01.2024	24,00	52,02	37,32	14,70	25,860	20,310	5,550	4,000	3,500	5,550	0,525
30.01.2024	24,00	52,67	37,51	15,16	25,600	20,300	5,300	4,000	3,500	5,300	0,524
31.01.2024	24,00	52,24	37,53	14,71	25,610	20,490	5,120	4,000	3,500	5,120	0,510
01.02.2024	24,00	54,60	38,89	15,71	25,700	20,450	5,250	4,000	3,500	5,250	0,545
02.02.2024	24,00	53,37	38,32	15,05	26,050	19,890	6,160	4,000	3,500	6,160	0,559
03.02.2024	24,00	53,85	38,31	15,54	25,980	19,870	6,110	4,000	3,500	6,110	0,566
04.02.2024	24,00	51,76	36,96	14,80	25,280	18,500	6,780	4,000	3,500	6,780	0,550
05.02.2024	24,00	51,96	38,18	13,78	23,220	17,690	5,530	4,000	3,500	5,530	0,470
06.02.2024	24,00	50,79	37,39	13,40	26,250	19,990	6,260	4,000	3,500	6,260	0,515
07.02.2024	24,00	50,87	36,96	13,91	25,840	19,350	6,490	4,000	3,500	6,490	0,528
08.02.2024	24,00	52,59	38,13	14,46	26,220	19,490	6,730	4,000	3,500	6,730	0,560
09.02.2024	24,00	52,02	35,50	16,52	30,680	13,270	17,410	4,000	3,500	17,410	0,933
10.02.2024	24,00	50,68	36,75	13,93	22,500	17,120	5,380	4,000	3,500	5,380	0,449
11.02.2024	24,00	55,16	39,49	15,67	26,720	20,130	6,590	4,000	3,500	6,590	0,602
12.02.2024	24,00	54,27	39,51	14,76	26,410	20,640	5,770	4,000	3,500	5,770	0,551
13.02.2024	24,00	52,80	39,26	13,54	26,300	20,050	6,250	4,000	3,500	6,250	0,530
14.02.2024	24,00	51,97	39,22	12,75	25,900	19,790	6,110	4,000	3,500	6,110	0,506
15.02.2024	24,00	50,85	38,80	12,05	26,010	20,550	5,460	4,000	3,500	5,460	0,465
16.02.2024	24,00	55,94	41,45	14,49	27,000	21,530	5,470	4,000	3,500	5,470	0,551
17.02.2024	24,00	56,27	42,16	14,11	27,100	21,150	5,950	4,000	3,500	5,950	0,562
18.02.2024	24,00	57,09	42,33	14,76	26,890	21,250	5,640	4,000	3,500	5,640	0,566
19.02.2024	24,00	54,90	41,20	13,70	26,930	20,950	5,980	4,000	3,500	5,980	0,546
20.02.2024	24,00	53,33	39,92	13,41	26,520	20,750	5,770	4,000	3,500	5,770	0,521
21.02.2024	24,00	54,45	40,37	14,08	26,140	20,590	5,550	4,000	3,500	5,550	0,524
22.02.2024	24,00	55,39	40,54	14,85	26,100	19,890	6,210	4,000	3,500	6,210	0,569
Среднее	24,00	53,18	38,66	14,52	25,838	19,600	6,238	4,000	3,500	6,238	0,544
Итого	768,00				826,810	627,200	199,610			199,610	17,409

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46

Подготовлен программным комплексом «Взлет СП». www.vzljot.ru