

Отчет о потреблении тепловой энергии за период с 23.02.2024 по 23.03.2024

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 1

Тип прибора: БКТ-7
Номер прибора: 212180

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
23.02.2024	24,00	52,96	38,80	14,16	26,520	19,490	7,030	4,000	3,500	7,030	0,571
24.02.2024	24,00	52,49	38,31	14,18	25,970	19,400	6,570	4,000	3,500	6,570	0,548
25.02.2024	24,00	53,20	39,02	14,18	26,860	20,190	6,670	4,000	3,500	6,670	0,564
26.02.2024	24,00	52,97	39,05	13,92	25,060	19,760	5,300	4,000	3,500	5,300	0,495
27.02.2024	24,00	52,71	39,72	12,99	24,260	19,120	5,140	4,000	3,500	5,140	0,462
28.02.2024	24,00	54,48	40,16	14,32	26,950	21,630	5,320	4,000	3,500	5,320	0,537
29.02.2024	24,00	52,98	39,62	13,36	27,070	21,540	5,530	4,000	3,500	5,530	0,519
01.03.2024	24,00	55,28	40,48	14,80	26,860	21,270	5,590	4,000	3,500	5,590	0,557
02.03.2024	24,00	54,22	40,28	13,94	27,310	20,880	6,430	4,000	3,500	6,430	0,566
03.03.2024	24,00	54,23	40,66	13,57	27,910	21,770	6,140	4,000	3,500	6,140	0,556
04.03.2024	24,00	56,00	41,81	14,19	27,390	22,290	5,100	4,000	3,500	5,100	0,537
05.03.2024	24,00	55,98	41,87	14,11	27,320	22,240	5,080	4,000	3,500	5,080	0,536
06.03.2024	24,00	54,41	41,30	13,11	27,220	21,730	5,490	4,000	3,500	5,490	0,516
07.03.2024	24,00	52,95	40,08	12,87	27,590	21,830	5,760	4,000	3,500	5,760	0,519
08.03.2024	24,00	54,54	40,91	13,63	27,440	21,930	5,510	4,000	3,500	5,510	0,533
09.03.2024	24,00	55,75	41,42	14,33	27,190	21,880	5,310	4,000	3,500	5,310	0,544
10.03.2024	24,00	56,83	41,41	15,42	27,620	20,940	6,680	4,000	3,500	6,680	0,624
11.03.2024	24,00	54,85	40,49	14,36	27,220	20,900	6,320	4,000	3,500	6,320	0,573
12.03.2024	24,00	53,77	40,30	13,47	27,100	22,000	5,100	4,000	3,500	5,100	0,510
13.03.2024	24,00	54,57	40,71	13,86	26,910	21,430	5,480	4,000	3,500	5,480	0,532
14.03.2024	24,00	55,02	41,13	13,89	26,800	21,710	5,090	4,000	3,500	5,090	0,519
15.03.2024	24,00	54,78	40,86	13,92	26,350	21,460	4,890	4,000	3,500	4,890	0,507
16.03.2024	24,00	52,39	39,41	12,98	26,150	20,870	5,280	4,000	3,500	5,280	0,486
17.03.2024	24,00	55,17	40,21	14,96	26,430	20,800	5,630	4,000	3,500	5,630	0,553
18.03.2024	24,00	53,95	39,94	14,01	26,670	19,900	6,770	4,000	3,500	6,770	0,568
19.03.2024	24,00	55,12	40,43	14,69	26,240	20,850	5,390	4,000	3,500	5,390	0,538
20.03.2024	24,00	52,66	39,45	13,21	26,510	20,980	5,530	4,000	3,500	5,530	0,503
21.03.2024	24,00	54,33	39,94	14,39	26,150	20,070	6,080	4,000	3,500	6,080	0,548
22.03.2024	24,00	50,53	38,60	11,93	25,190	19,500	5,690	4,000	3,500	5,690	0,458
23.03.2024	24,00	52,35	39,37	12,98	27,210	20,400	6,810	4,000	3,500	6,810	0,546
Среднее	24,00	54,05	40,19	13,86	26,716	20,959	5,757	4,000	3,500	5,757	0,534
Итого	720,00				801,470	628,760	172,710			172,710	16,025

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru