

Отчет о потреблении тепловой энергии за период с 21.11.2023 по 21.12.2023

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 2

Тип прибора: БКТ-7
Номер прибора: 202114

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
21.11.2023	24,00	53,06	40,66	12,40	25,820	21,810	4,010	2,000	1,900	4,010	0,426
22.11.2023	24,00	52,42	40,31	12,11	25,270	21,510	3,760	2,000	1,900	3,760	0,404
23.11.2023	24,00	53,65	41,17	12,48	25,730	21,960	3,770	2,000	1,900	3,770	0,420
24.11.2023	24,00	52,16	40,22	11,94	25,450	22,100	3,350	2,000	1,900	3,350	0,393
25.11.2023	24,00	52,60	40,63	11,97	25,530	21,430	4,100	2,000	1,900	4,100	0,415
26.11.2023	24,00	51,59	40,28	11,31	25,820	21,960	3,860	2,000	1,900	3,860	0,395
27.11.2023	24,00	52,55	40,62	11,93	25,230	21,210	4,020	2,000	1,900	4,020	0,408
28.11.2023	24,00	54,29	41,64	12,65	25,750	22,010	3,740	2,000	1,900	3,740	0,427
29.11.2023	24,00	52,78	41,18	11,60	25,850	22,390	3,460	2,000	1,900	3,460	0,392
30.11.2023	24,00	52,23	40,81	11,42	25,750	22,010	3,740	2,000	1,900	3,740	0,394
01.12.2023	24,00	53,87	41,82	12,05	25,790	21,940	3,850	2,000	1,900	3,850	0,416
02.12.2023	24,00	53,07	41,65	11,42	25,910	21,830	4,080	2,000	1,900	4,080	0,408
03.12.2023	24,00	50,62	40,33	10,29	26,330	21,840	4,490	2,000	1,900	4,490	0,393
04.12.2023	24,00	50,19	40,07	10,12	26,050	22,270	3,780	2,000	1,900	3,780	0,364
05.12.2023	24,00	52,95	41,18	11,77	25,600	22,320	3,280	2,000	1,900	3,280	0,388
06.12.2023	24,00	53,45	42,06	11,39	25,840	22,650	3,190	2,000	1,900	3,190	0,380
07.12.2023	24,00	51,71	41,52	10,19	26,510	23,330	3,180	2,000	1,900	3,180	0,356
08.12.2023	24,00	49,78	40,01	9,77	25,840	22,730	3,110	2,000	1,900	3,110	0,325
09.12.2023	24,00	50,38	40,42	9,96	25,570	22,650	2,920	2,000	1,900	2,920	0,320
10.12.2023	24,00	51,29	40,86	10,43	26,610	22,820	3,790	2,000	1,900	3,790	0,365
11.12.2023	24,00	52,82	41,12	11,70	25,200	21,870	3,330	2,000	1,900	3,330	0,370
12.12.2023	24,00	48,54	40,25	8,29	26,240	22,340	3,900	2,000	1,900	3,900	0,313
13.12.2023	24,00	46,91	38,37	8,54	26,310	22,250	4,060	2,000	1,900	4,060	0,322
14.12.2023	24,00	49,60	39,74	9,86	25,870	22,210	3,660	2,000	1,900	3,660	0,341
15.12.2023	24,00	49,93	40,03	9,90	25,700	21,750	3,950	2,000	1,900	3,950	0,355
16.12.2023	24,00	49,76	39,87	9,89	26,550	21,900	4,650	2,000	1,900	4,650	0,381
17.12.2023	24,00	49,29	38,95	10,34	27,400	22,630	4,770	2,000	1,900	4,770	0,401
18.12.2023	24,00	51,59	40,60	10,99	26,830	23,070	3,760	2,000	1,900	3,760	0,387
19.12.2023	24,00	49,20	39,14	10,06	26,770	22,030	4,740	2,000	1,900	4,740	0,388
20.12.2023	24,00	48,79	39,22	9,57	26,590	22,760	3,830	2,000	1,900	3,830	0,345
21.12.2023	24,00	49,60	39,82	9,78	26,870	23,290	3,580	2,000	1,900	3,580	0,347
Среднее	24,00	51,31	40,47	10,84	26,019	22,222	3,797	2,000	1,900	3,797	0,379
Итого	744,00				806,580	688,870	117,710			117,710	11,739

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru