

Отчет о потреблении тепловой энергии за период с 22.12.2023 по 21.01.2024

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 2

Тип прибора: БКТ-7
Номер прибора: 202114

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
22.12.2023	24,00	52,93	41,87	11,06	26,420	22,600	3,820	2,000	1,900	3,820	0,392
23.12.2023	24,00	49,40	39,63	9,77	26,670	22,700	3,970	2,000	1,900	3,970	0,362
24.12.2023	24,00	48,69	38,36	10,33	27,490	22,330	5,160	2,000	1,900	5,160	0,409
25.12.2023	24,00	47,92	37,99	9,93	27,580	22,160	5,420	2,000	1,900	5,420	0,406
26.12.2023	24,00	49,50	39,09	10,41	16,760	14,460	2,300	2,000	1,900	2,300	0,227
27.12.2023	24,00	49,14	39,42	9,72	26,540	21,860	4,680	2,000	1,900	4,680	0,375
28.12.2023	24,00	51,15	40,52	10,63	28,290	24,450	3,840	2,000	1,900	3,840	0,394
29.12.2023	24,00	54,29	43,09	11,20	29,500	24,880	4,620	2,000	1,900	4,620	0,453
30.12.2023	24,00	54,31	43,27	11,04	30,250	25,250	5,000	2,000	1,900	5,000	0,472
31.12.2023	24,00	54,59	43,54	11,05	30,060	25,090	4,970	2,000	1,900	4,970	0,469
01.01.2024	24,00	56,42	44,34	12,08	28,460	24,290	4,170	2,000	1,900	4,170	0,460
02.01.2024	24,00	55,52	44,05	11,47	29,060	24,420	4,640	2,000	1,900	4,640	0,456
03.01.2024	24,00	53,99	42,97	11,02	29,270	25,200	4,070	2,000	1,900	4,070	0,428
04.01.2024	24,00	52,64	42,15	10,49	29,270	25,070	4,200	2,000	1,900	4,200	0,410
05.01.2024	24,00	52,13	41,75	10,38	29,460	24,980	4,480	2,000	1,900	4,480	0,422
06.01.2024	24,00	54,50	43,35	11,15	29,010	24,510	4,500	2,000	1,900	4,500	0,445
07.01.2024	24,00	52,58	42,14	10,44	28,740	25,020	3,720	2,000	1,900	3,720	0,389
08.01.2024	24,00	52,69	42,44	10,25	29,310	24,850	4,460	2,000	1,900	4,460	0,413
09.01.2024	24,00	52,03	41,55	10,48	29,230	24,600	4,630	2,000	1,900	4,630	0,426
10.01.2024	24,00	53,92	42,25	11,67	29,340	24,980	4,360	2,000	1,900	4,360	0,455
11.01.2024	24,00	53,94	42,50	11,44	29,660	25,320	4,340	2,000	1,900	4,340	0,443
12.01.2024	24,00	51,98	40,90	11,08	29,120	24,240	4,880	2,000	1,900	4,880	0,445
13.01.2024	24,00	54,07	41,62	12,45	29,570	24,370	5,200	2,000	1,900	5,200	0,501
14.01.2024	24,00	53,49	43,84	9,65	29,160	25,270	3,890	2,000	1,900	3,890	0,384
15.01.2024	24,00	46,16	37,95	8,21	13,350	8,340	5,010	2,000	1,900	5,010	0,234
16.01.2024	24,00	50,45	41,82	8,63	16,650	11,470	5,180	2,000	1,900	5,180	0,290
17.01.2024	24,00	51,57	41,83	9,74	23,310	17,610	5,700	2,000	1,900	5,700	0,373
18.01.2024	24,00	54,18	45,89	8,29	44,350	40,660	3,690	2,000	1,900	3,690	0,444
19.01.2024	24,00	52,50	43,87	8,63	36,790	32,500	4,290	2,000	1,900	4,290	0,404
20.01.2024	24,00	53,41	42,26	11,15	28,620	24,020	4,600	2,000	1,900	4,600	0,444
21.01.2024	24,00	52,18	41,20	10,98	29,490	24,740	4,750	2,000	1,900	4,750	0,443
Среднее	24,00	52,33	41,85	10,48	28,090	23,621	4,469	2,000	1,900	4,469	0,409
Итого	744,00				870,780	732,240	138,540			138,540	12,668

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru