

Отчет о потреблении тепловой энергии за период
с 22.01.2024 по 22.02.2024

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 2

Тип прибора: БКТ-7
Номер прибора: 202114

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
22.01.2024	24,00	50,55	39,14	11,41	21,420	17,180	4,240	2,000	1,900	4,240	0,348
23.01.2024	24,00	52,73	40,15	12,58	27,120	22,620	4,500	2,000	1,900	4,500	0,453
24.01.2024	24,00	54,01	41,35	12,66	26,650	22,700	3,950	2,000	1,900	3,950	0,435
25.01.2024	24,00	51,21	39,74	11,47	26,990	22,360	4,630	2,000	1,900	4,630	0,425
26.01.2024	24,00	50,59	39,49	11,10	26,780	22,910	3,870	2,000	1,900	3,870	0,388
27.01.2024	24,00	53,33	41,47	11,86	28,530	24,300	4,230	2,000	1,900	4,230	0,448
28.01.2024	24,00	51,79	40,35	11,44	24,650	19,920	4,730	2,000	1,900	4,730	0,401
29.01.2024	24,00	51,02	39,50	11,52	27,320	22,710	4,610	2,000	1,900	4,610	0,428
30.01.2024	24,00	51,70	39,68	12,02	27,100	22,240	4,860	2,000	1,900	4,860	0,441
31.01.2024	24,00	51,32	39,53	11,79	27,150	22,670	4,480	2,000	1,900	4,480	0,425
01.02.2024	24,00	53,58	41,28	12,30	27,150	22,570	4,580	2,000	1,900	4,580	0,446
02.02.2024	24,00	52,58	41,15	11,43	27,540	23,160	4,380	2,000	1,900	4,380	0,422
03.02.2024	24,00	53,18	41,15	12,03	27,480	22,880	4,600	2,000	1,900	4,600	0,448
04.02.2024	24,00	51,85	40,56	11,29	26,780	22,540	4,240	2,000	1,900	4,240	0,407
05.02.2024	24,00	51,47	41,14	10,33	24,020	19,180	4,840	2,000	1,900	4,840	0,373
06.02.2024	24,00	50,15	40,10	10,05	27,320	23,250	4,070	2,000	1,900	4,070	0,378
07.02.2024	24,00	50,24	40,21	10,03	26,860	22,510	4,350	2,000	1,900	4,350	0,384
08.02.2024	24,00	51,97	41,34	10,63	27,180	23,100	4,080	2,000	1,900	4,080	0,392
09.02.2024	24,00	51,44	42,16	9,28	31,760	27,560	4,200	2,000	1,900	4,200	0,395
10.02.2024	24,00	50,01	39,70	10,31	23,040	19,380	3,660	2,000	1,900	3,660	0,329
11.02.2024	24,00	54,00	42,57	11,43	26,390	22,190	4,200	2,000	1,900	4,200	0,409
12.02.2024	24,00	53,27	41,83	11,44	26,370	22,090	4,280	2,000	1,900	4,280	0,414
13.02.2024	24,00	51,86	41,36	10,50	26,770	22,620	4,150	2,000	1,900	4,150	0,388
14.02.2024	24,00	51,26	40,76	10,50	27,050	22,850	4,200	2,000	1,900	4,200	0,397
15.02.2024	24,00	50,15	40,03	10,12	27,110	23,150	3,960	2,000	1,900	3,960	0,369
16.02.2024	24,00	54,98	42,82	12,16	28,010	23,380	4,630	2,000	1,900	4,630	0,458
17.02.2024	24,00	55,09	43,13	11,96	28,120	23,920	4,200	2,000	1,900	4,200	0,442
18.02.2024	24,00	55,88	43,45	12,43	28,070	23,920	4,150	2,000	1,900	4,150	0,450
19.02.2024	24,00	53,78	42,19	11,59	28,220	23,750	4,470	2,000	1,900	4,470	0,447
20.02.2024	24,00	52,62	40,70	11,92	27,900	22,620	5,280	2,000	1,900	5,280	0,468
21.02.2024	24,00	53,31	41,16	12,15	27,400	22,790	4,610	2,000	1,900	4,610	0,444
22.02.2024	24,00	54,18	41,67	12,51	27,290	22,880	4,410	2,000	1,900	4,410	0,455
Среднее	24,00	52,35	40,96	11,38	26,923	22,559	4,364	2,000	1,900	4,364	0,416
Итого	768,00				861,540	721,900	139,640			139,640	13,307

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljot.ru