

Отчет о потреблении тепловой энергии за период с 23.02.2024 по 23.03.2024

Потребитель: Жилой дом
Адрес: п. Сосновый, дом 2

Тип прибора: БКТ-7
Номер прибора: 202114

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
23.02.2024	24,00	51,88	40,73	11,15	27,740	23,150	4,590	2,000	1,900	4,590	0,430
24.02.2024	24,00	51,43	40,36	11,07	27,150	23,680	3,470	2,000	1,900	3,470	0,388
25.02.2024	24,00	52,21	40,78	11,43	28,120	23,020	5,100	2,000	1,900	5,100	0,454
26.02.2024	24,00	51,91	40,55	11,36	26,140	22,020	4,120	2,000	1,900	4,120	0,399
27.02.2024	24,00	51,42	40,92	10,50	24,040	19,900	4,140	2,000	1,900	4,140	0,358
28.02.2024	24,00	53,01	41,62	11,39	26,530	21,570	4,960	2,000	1,900	4,960	0,432
29.02.2024	24,00	51,63	40,46	11,17	26,780	21,760	5,020	2,000	1,900	5,020	0,428
01.03.2024	24,00	53,80	41,34	12,46	26,470	21,890	4,580	2,000	1,900	4,580	0,447
02.03.2024	24,00	52,83	41,34	11,49	26,910	23,040	3,870	2,000	1,900	3,870	0,405
03.03.2024	24,00	52,96	41,54	11,42	27,510	23,360	4,150	2,000	1,900	4,150	0,419
04.03.2024	24,00	54,61	42,49	12,12	26,960	22,970	3,990	2,000	1,900	3,990	0,427
05.03.2024	24,00	54,53	42,67	11,86	27,170	22,770	4,400	2,000	1,900	4,400	0,439
06.03.2024	24,00	53,55	42,81	10,74	27,410	23,320	4,090	2,000	1,900	4,090	0,404
07.03.2024	24,00	52,02	41,53	10,49	27,920	23,000	4,920	2,000	1,900	4,920	0,425
08.03.2024	24,00	53,39	42,26	11,13	27,600	23,170	4,430	2,000	1,900	4,430	0,419
09.03.2024	24,00	54,22	42,65	11,57	27,320	23,390	3,930	2,000	1,900	3,930	0,417
10.03.2024	24,00	55,29	42,91	12,38	27,730	23,730	4,000	2,000	1,900	4,000	0,445
11.03.2024	24,00	53,54	41,38	12,16	27,460	23,970	3,490	2,000	1,900	3,490	0,412
12.03.2024	24,00	52,49	40,42	12,07	27,440	23,100	4,340	2,000	1,900	4,340	0,444
13.03.2024	24,00	53,43	41,26	12,17	27,250	23,300	3,950	2,000	1,900	3,950	0,425
14.03.2024	24,00	53,90	41,84	12,06	27,100	23,010	4,090	2,000	1,900	4,090	0,428
15.03.2024	24,00	53,46	41,19	12,27	26,640	22,330	4,310	2,000	1,900	4,310	0,433
16.03.2024	24,00	51,22	39,94	11,28	26,430	22,540	3,890	2,000	1,900	3,890	0,389
17.03.2024	24,00	53,86	41,51	12,35	26,560	22,470	4,090	2,000	1,900	4,090	0,426
18.03.2024	24,00	52,73	40,96	11,77	26,780	22,690	4,090	2,000	1,900	4,090	0,416
19.03.2024	24,00	53,78	41,36	12,42	26,270	22,620	3,650	2,000	1,900	3,650	0,414
20.03.2024	24,00	51,49	40,15	11,34	26,630	22,390	4,240	2,000	1,900	4,240	0,408
21.03.2024	24,00	52,93	40,88	12,05	26,230	22,440	3,790	2,000	1,900	3,790	0,412
22.03.2024	24,00	49,99	39,36	10,63	25,090	20,610	4,480	2,000	1,900	4,480	0,379
23.03.2024	24,00	51,32	40,28	11,04	26,850	22,780	4,070	2,000	1,900	4,070	0,399
Среднее	24,00	52,83	41,25	11,58	26,874	22,666	4,208	2,000	1,900	4,208	0,417
Итого	720,00				806,230	679,990	126,240			126,240	12,521

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru