

Отчет о потреблении тепловой энергии за период с 22.03.2024 по 20.04.2024

Потребитель: Жилой дом

Тип прибора: БКТ-7

Адрес: г. Туапсе, ул. Звёздная, д. 39 блок 1

Номер прибора: 110747

Дата	Теплосистема 2 - ГВС									Итого по ТС2	
	ВР, ч	t3, °C	t4, °C	dt, °C	V3, м³	V4, м³	Vгвс, м³	P3, кг/м³	P4, кг/м³	Vгвс, м³	W, Гкал
22.03.2024	24,00	36,33	32,70	3,63	16,330	12,750	3,580	5,000	5,000	3,580	0,139
23.03.2024	24,00	39,36	34,63	4,73	16,190	11,370	4,820	5,000	5,000	4,820	0,189
24.03.2024	24,00	43,11	37,40	5,71	17,530	12,040	5,490	5,000	5,000	5,490	0,248
25.03.2024	24,00	44,07	38,41	5,66	16,730	11,880	4,850	5,000	5,000	4,850	0,227
26.03.2024	24,00	43,79	37,98	5,81	16,450	12,220	4,230	5,000	5,000	4,230	0,206
27.03.2024	24,00	47,28	39,97	7,31	16,800	11,730	5,070	5,000	5,000	5,070	0,265
28.03.2024	24,00	51,89	43,34	8,55	16,980	11,740	5,240	5,000	5,000	5,240	0,310
29.03.2024	24,00	53,50	44,92	8,58	16,580	12,300	4,280	5,000	5,000	4,280	0,286
30.03.2024	24,00	52,89	44,57	8,32	16,830	12,120	4,710	5,000	5,000	4,710	0,296
31.03.2024	23,00	56,26	47,05	9,21	16,510	12,010	4,500	5,000	5,000	4,500	0,315
01.04.2024	24,00	54,06	45,47	8,59	15,920	12,550	3,370	5,000	5,000	3,370	0,253
02.04.2024	24,00	54,00	45,32	8,68	16,610	12,270	4,340	5,000	5,000	4,340	0,288
03.04.2024	24,00	54,36	45,95	8,41	16,830	12,760	4,070	5,000	5,000	4,070	0,286
04.04.2024	24,00	54,60	46,07	8,53	17,100	12,740	4,360	5,000	5,000	4,360	0,300
05.04.2024	24,00	53,77	45,13	8,64	16,910	12,260	4,650	5,000	5,000	4,650	0,302
06.04.2024	24,00	54,56	45,83	8,73	17,250	12,890	4,360	5,000	5,000	4,360	0,301
07.04.2024	24,00	52,77	44,76	8,01	18,020	12,980	5,040	5,000	5,000	5,040	0,314
08.04.2024	24,00	54,94	46,12	8,82	17,640	13,360	4,280	5,000	5,000	4,280	0,307
09.04.2024	24,00	54,56	46,09	8,47	17,530	13,600	3,930	5,000	5,000	3,930	0,288
10.04.2024	24,00	54,90	46,37	8,53	17,440	13,760	3,680	5,000	5,000	3,680	0,280
11.04.2024	24,00	54,64	45,96	8,68	16,990	13,260	3,730	5,000	5,000	3,730	0,280
12.04.2024	24,00	55,54	46,52	9,02	17,590	13,150	4,440	5,000	5,000	4,440	0,316
13.04.2024	24,00	55,44	46,72	8,72	17,250	13,230	4,020	5,000	5,000	4,020	0,300
14.04.2024	24,00	55,75	46,83	8,92	18,000	13,240	4,760	5,000	5,000	4,760	0,331
15.04.2024	24,00	54,10	45,20	8,90	17,060	12,800	4,260	5,000	5,000	4,260	0,295
16.04.2024	24,00	54,78	45,51	9,27	16,940	12,530	4,410	5,000	5,000	4,410	0,308
17.04.2024	24,00	53,06	44,69	8,37	17,390	12,880	4,510	5,000	5,000	4,510	0,300
18.04.2024	24,00	54,52	45,84	8,68	16,680	13,030	3,650	5,000	5,000	3,650	0,272
19.04.2024	24,00	57,67	48,11	9,56	17,320	13,410	3,910	5,000	5,000	3,910	0,311
20.04.2024	24,00	56,08	47,02	9,06	17,860	12,850	5,010	5,000	5,000	5,010	0,345
Среднее	23,97	52,09	44,02	8,07	17,042	12,657	4,385	5,000	5,000	4,385	0,282
Итого	719,00				511,260	379,710	131,550			131,550	8,458

Механические показания: V1=_____ V2=_____

Отчет подготовил: Инженер-диспетчер _____ / Антипов М. Е. /



ООО «Энергострой», Россия, Краснодарский край, г. Туапсе, ул. Ленинградская, 11 блок 2
e-mail: energostroy-tuapse@mail.ru, URL: www.e-stroy.org
тел. 8 (86167) 5-36-00, +7(918) 339-50-67, 033-22-46



Подготовлен программным комплексом «Взлет СП». www.vzljet.ru